# Renovations to:

# Glenbrook Community Center


35 Crescent Street
Stamford, Connecticut. 06906


May 25, 2004

ABBREVIATIONS ANCHOR BOLT LOCATION LOW POINT LOC. L.P. A.C.P. ASBESTOS CEMENT PIPE ADJUSTABLE ADJ. LTG. LIGHTING A.F.F. ABOVE FINISH FLOOR ACOUSTICAL CEILING TILE AC.T. ALUM. ALUMINUM APPROXIMATE APPROX. MASONRY ARCHITECTURAL ARCH. MAXIMUM ASPHALT ASPH. MECHANICAL AVG. AVERAGE M.H. MANHOLE MIN. MISC. MINIMUM BASEMENT MISCELLANEOUS M.O. MASONRY OPENING BEARING MTD. MOUNTED BRK. BRICK BITUMINOUS BLK. NOT APPLICABLE BLDG. BUILDING N.I.C. NOT IN CONTRACT B.S. BOTH SIDES NUMBER NOM. NOMINAL NEAR SIDE CAST IN PLACE CONCRETE N.T.S. NOT TO SCALE CATCH BASIN C.B.R. CATCH BASIN TO BE REMOVED ON CENTER CLG. OCCUPANT OUTSIDE DIAMETER CENTER LINE CHALK BOARD OPNG. OPENING CLEAN OUT COL. CONC. CONF. COLUMN PAINTED CONCRETE BLOCK P.C.B. CONCRETE P.G.B. PAINTED GYPSUM BOARD CONFERENCE C.M.U. CONT. CONCRETE MASONRY UNIT PLUMBING CONTINUOUS, CONTINUE PLYWD. PLYWOOD CONTROL JOINT/CONSTR. JOINT CONTR. PREP. PREPARATION CONTRACTOR PRESSURE TREATED PAINTED DET. P.V.C. POLYVINYL CHLORIDE DIAMETER DIA. DIMENSION RAD. RADIUS DR. DOOR R.C.P. REINFORCED CONC. PIPE DN. DWG. DOWN DRAWING REINF. REINFORCEMENT REQUIRED R.H. ROOF HATCH ELECTRICAL ROOF LEADER ECTR. EXISTING CEILING TO REMAIN ROOM EDUCATION ELEC. ELECTRICAL SANITARY E.F. EACH FACE SEALED CONCRETE E.J. EXPANSION JOINT SCHED. SECT. S.F. SCHEDULE FI EVATION SECTION STEP FOOTING ELEVATION EMER. **EMERGENCY** SIMILAR ENCLOSURE ENCL. S.O.G. SPEC. SLAB ON GRADE ENLARGED SPECIFICATIONS ENT. ENTRANCE EPOXY PAINT SQUARE FEET EQ. STL. STRUCT. EXPOSED STRUCTURE ES. E.T.R. STRUCTURAL EXISTING TO REMAIN SUSPENDED, SUSPENSION SUSP. FACH WAY SHEAR WALL SHEAR WALL FOOTING S.W. S.W.F. E.W./E.F. EACH WAY/EACH FACE EXAM. EXAMINATION **EXPANSION** TELEPHONE T&B EXT. EXTERIOR TOP & BOTTOM TECH. TECHNOLOGY TOP OF FOUNDATION T.O.F. T.O.S. T.T.F. TOP OF FRAME F.F. FINISHED FLOOR TOP OF STEEL FIN. FINISH, FINISHED FIXT. FIXTURE TOP OF SLAB FLOOR TOP OF WALL TYPICAL FAR SIDE UNLESS OTHERWISE NOTED GAS GAGE, GAUGE GENERAL GENERAL CONTRACTOR VINYL BASE GA. GEN. G.C. GWB GYP. GYP. BD. VINYL COMPOSITE TILE VERT. V.I.F. VERTICAL GYPSUM WALL BOARD VERIFY IN FIELD GYPSUM GYPSUM BOARD WATER HANDICAPPED WALL CONTROL JOINT HD. HDWE. HGT. H.P. HEADED WOOD HARDWARE WIDE FLANGE HEIGHT W.W.F. WELDED WIRE FABRIC HIGH POINT W.W.M. WELDED WIRE MESH H.M. HORIZ. H.B. HR. HOLLOW METAL HORIZONTAL, HORIZONTALLY HOSE BIBB HOUR DIAMETER HYD. HYDRANT INSULATION, INSULATED INTERIOR INT.

SYMBOL LEGEND (xxx)ROOM NUMBER DOOR NUMBER DEMOLITION NOTE DETAIL NUMBER DRAWING NUMBER CONSTRUCTION NOTE SECTION / DETAIL DRAWING NUMBER WALL SECTION DRAWING NUMBER INTERIOR / EXTERIOR ELEVATION DRAWING NUMBER REFERENCE POINT WALL TYPE REVISION MARK

# GRAPHIC LEGEND CONCRETE CONCRETE MASONRY UNITS BRICK STONE METALS EARTH PLYWOOD





# LIST OF DRAWINGS

# ARCHITECTURAL DRAWINGS

- COVER SHEET A1 - GENERAL INFORMATION
- A2 CODE PLANS AND INFORMATION C1 - SITE PLAN AND DETAILS
- A3 PHASING PLANS
- A4 DEMOLITION PLANS A5 - BASEMENT FLOOR PLAN
- A6 FIRST FLOOR PLAN
- A7 SECOND FLOOR PLAN A8 - THIRD FLOOR PLAN
- A9 BASEMENT REFLECTED CEILING PLAN A10 - FIRST FLOOR REFLECTED CEILING PLAN
- A11 SECOND FLOOR REFLECTED CEILING PLAN A12 - THIRD FLOOR REFLECTED CEILING PLAN
- A13 DOOR AND ROOM FINISH SCHEDULES A14 - PARTITIONS AND INTERIOR ELEVATIONS
- A15 ELEVATIONS A16 - WINDOW ELEVATIONS AND DETAILS

# MECHANICAL DRAWINGS ME1 - GENERAL NOTES AND LEGENDS

- M1 BASEMENT MECHANICAL PLAN M2 - FIRST FLOOR MECHANICAL PLAN
- M3 SECOND FLOOR MECHANICAL PLAN M4 - THIRD FLOOR MECHANICAL PLAN
- M5 MECHANICAL SCHEDULES AND DETAILS

# PLUMBING DRAWINGS

- P1 BASEMENT PLUMBING PLAN P2 - FIRST FLOOR PLUMBING PLAN P3 - SECOND FLOOR PLUMBING PLAN
- P4 THIRD FLOOR PLUMBING PLAN P5 - SITE PLAN PLUMBING SCHEDULE
- FIRE PROTECTION DRAWINGS FP1 - BASEMENT SPRINKLER PLAN FP2 - FIRST FLOOR SPRINKLER PLAN
- FP3 SECOND FLOOR SPRINKLER PLAN FP4 - THIRD FLOOR SPRINKLER PLAN

# **ELECTRICAL DRAWINGS**

FP5 - FIRE PROTECTION DETAILS

- e1 BASEMENT ELECTRICAL PLAN e2 - first FLOOR ELECTRICAL PLAN e3 - second floor ELECTRICAL PLAN e4 - THIRD floor ELECTRICAL PLAN
- e5 electrical SCHEDULES AND DETAILS

# GENERAL NOTES

- 1. CONTRACTOR TO FIELD VERIFY ALL EXISTING CONDITIONS & DIMENSIONS
- 2. ALL MATERIALS & EQUIPMENT ARE NEW UNLESS OTHERWISE

CONTRACTOR TO FIELD VERIFY EXACT LOCATIONS

- NOTED AS "EXISTING" 3. ALL EXISTING UTILITIES & EQUIPMENT LOCATIONS ARE APPROXIMATE
- 4. CONTRACTOR ASSUMES ALL RESPONSIBILITY DURING CONSTRUCTION AND WILL REPLACE ANY & ALL DAMAGED ITEMS & EQUIPMENT WITH NO ADDITIONAL COST TO THE OWNER
- 5. ALL RATED DOORS SHALL HAVE POSITIVE LATCHING LOCKSETS OR LATCHSETS AND CLOSERS
- 6. ALL DOORS LEADING TO HAZARDOUS AREAS SHALL HAVE TACTILE
- 7. ALL DOORS EXITING 100 PERSONS OR MORE SHALL HAVE PANIC EXIT DEVICES
- 8. ALL HANDICAPPED ACCESSIBLE DOOR HARDWARE SHALL BE PROVIDED
- TO COMPLY WITH UNIFORM FEDERAL ACCESSIBILITY STANDARDS 9. ALL HAZARDOUS AREAS SHALL HAVE A MINIMUM OF 45 MINUTE
- DOORS, FRAMES & HARDWARE
- 10. HAZARDOUS AREAS INCLUDE: CUSTODIAN SPACES, STORAGE ROOMS, AND MECHANICAL ROOMS.
- 11. THE CONTRACTOR SHALL INSURE THAT ITEMS 5 THROUGH 10 ARE IMPLEMENTED IN NEW & EXISTING BUILDING AREAS
- 12. ITEMS 5 THROUGH 11 ARE A MINIMUM STANDARD REFER TO DOOR SCHEDULE ON DRAWING A13 FOR EXACT REQUIREMENTS OF ALL DOORS, FRAMES & HARDWARE
- 13. ALL PROGRAMS ARE NOT ACCESSIBLE TO THE HANDICAPPED. ALL ROOMS USED BY THE HANDICAPPED HAVE ACCESSIBLE WORK STATIONS, HANDICAPPED SINKS WITH PIPE PROTECTION, ALL ACCESSORIES ARE MOUNTED 48" MAXIMUM FOR SIDE APPROACH OR 48" MAXIMUM FOR FRONT APPROACH, THE ACCESSIBLE ROUTE THROUGH BUILDING IS SIGNED WITH THE INTERNATIONAL SYMBOL OF ACCESSIBILITY AND THE ACCESSIBLE ROUTE HAS 36" CLEARANCE THROUGHOUT (32" CLEARANCE FOR DOORWAYS). ALL ITEMS SHALL COMPLY WITH SECTION 504, REHABILITATION ACT 1973
- 15. ALL PROGRAM SPACES HAVE BEEN IDENTIFIED ON THE CODE SHEET DRAWING A2. ALL NEW ROOMS OR AREAS REQUIRING WORK ARE FURTHER IDENTIFIED BY A ROOM DESIGNATION SYMBOL (101) & LISTED ON ALL OTHER PLANS

SITE LOCATION MAP

RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET STAMFORD, CONNECTICUT 06906

INVERT

**JANITOR** 

K.P.

LAM. L.F.

KICK PLATE

LAMINATE

LINEAL FOOT


12/30/2005

GENERAL INFORMATION


Drawing Number: MAY 25, 2004

Project Number:

AS NOTED



# exist. stone retaining wall to remain $\leftarrow$ 11 $\rightarrow$ extent of paving existing building 00 exist. m.h. crescent street



☐ ☐ SILT FENCE HAYBAILS. SEE DETAIL W/SP2 —— e ——— electrical line — t — telephone line ——s —— sanitary LINE ——— G ——— GAS LINE NEW BITUMINOUS PAVING SEE GEN. NOTE # M.H.

SYMBOL LEGEND

<del>\_o\_</del> X site signage SEE SIGN LEGEND

------ PROPERTY LINE

A PAINTED H.C. PARKING SYMBOL

SEE NOTE #

NEW PAINTED STRIPING SEE

== EXISTING BIT. CURBING TO BE REMOVED

EXISTING BIT. CURB ING TO BE REMAIN

1 SITE NOTE EXISTING MANHOLE TO REMAIN PLAN, SECTION, DETAIL
SHEET NUMBER general site notes PRIOR TO ANY EXCAVATION, CONTRACTOR TO NOTIFY 'CALL BEFORE YOU DIG', 1.800.922.4455. CONSTRUCTION NOTES remove cover and clean existing yard drain snake out piping to the nearest manhole. provide 6' tall galv. chain link fencing, including man gates and vehicle gate. remove exist. fence and patch exist. stone wall at old sleeve connections . remove existing tree stump and fencing and provide process for new bituminous paving 4. trench and backfill for new sprinkler water service from main in street to building. patch paving in street as required. see pipe bedding detail this sheet. 5. provide decorative pole lights and all associated underground wiring, trenching etc. see electrical dwgs for additional information.

6. provide new bituminous concrete paving, including milling of exist. paving, process sub—base, base and top coats. see specification for more information.

7. fill and patch existing potholes with bituminous

provide sink and all associated piping and sanitary connections. see plumbing dwgs for more information.

conc. paving.

RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER 35 CRESCENT STREET STAMFORD, CONNECTICUT 06906



SILVER / PETRUCELLI + ASSOCIATES Architects

3190 Whitney Avenue, Hamden, CT 06518-2340 Tel. 203 230 9007 Fax. 203 230 8247 silverpetrucelli.com

Date: Revised By:

SITE PLAN AND DETAILS

Drawing Title:


FEBRUARY 12, 2004 1/4" = 1'-0"Drawn By:


PEJ


03.57


Project Number:


Drawing Number:











SYMBOL LEGEND

- EXISTING WALLS TO REMAIN

- EXISTING TO BE REMOVED

— NEW gypsum board/stud wall PARTITIONS

- DOOR NUMBER - SEE DOOR SCHED. ON DWG. a13

- ROOM NUMBER - SEE RM. FIN. SCHED. ON DWG. A13

— DEMOLITION NOTES — SEE DEMO plans a4

window TYPES - SEE sheet A16

1 - PARTITION TYPES - SEE sheet A14

 ELEVATION OR SECTION NUMBER SHEET NUMBER

> - PLAN, SECTION, DETAIL, OR ELEV. NUMBER SHEET NUMBER

1 — — construction notes — SEE plans A5 through a8

# GENERAL NOTES

- . CONTRACTOR TO FIELD VERIFY ALL EXISTING CONDITIONS & DIMENSIONS
- 2. ALL DIMENSIONS ARE TO OUTSIDE FACE OF BRICK,
- CONCRETE BLOCK OR GYPSUM BOARD 3. ALL H.C. ACCESSIBLE ROOMS TO RECEIVE H.C. SIGNAGE
- AT DOOR SEE DOOR SCHEDULE, sheet A13 4. FOR NEW WORK BEING DONE ON EXISTING DOORS & FRAMES
- SEE DOOR SCHEDULE, sheet A13 5. SEAL ALL DUCT & PIPE PENETRATIONS THROUGH RATED WALLS WITH SAFING INSULATION - SEE code information sheet
- for LOCATIONS OF ALL FIRE RATED PARTITIONS SEE SPECS. 6. PATCH ALL EXISTING CONCRETE BLOCK WALLS AFFECTED
- BY NEW WORK 7. PATCH ALL EXISTING GYPSUM BOARD AND ACOUSTICAL CEILINGS AFFECTED BY NEW WORK
- 8. PATCH ALL EXISTING VCT FLOORING AND RUBBER BASE

WINDOW PANES (ALLOW FOR 5% REPLACEMENT)

AFFECTED BY NEW WORK 9. BASE BID: FOR EXISTING WINDOWS AT TYPE A1 DISCONNECT OPERATOR TO TOP OPERABLE WINDOW AND REMOVE GLAZING FOR MECH. LOUVERS (L2). CONTRACTOR TO REPLACE ALL EXISTING BROKEN SCREENS (ALLOW FOR 10% REPLACEMENT) AND BROKEN

# hc toilet EQUIPMENT LEGEND

1

1)—

- 1. 2'x3' MIRROR MOUNTED 3'-4" A.F.F. TO BOTTOM OF MIRROR
- 2. 30" SWING AWAY GRAB BAR MTD 36" ABOVE FINISH FLOOR 3. 42" GRAB BAR - MOUNTED 36" ABOVE FINISH FLOOR
- 4. 36" GRAB BAR MOUNTED 33" ABOVE FINISH FLOOR 5. H.C. SOAP DISPENSER - SURFACE MOUNTED
- provided by owner 6. H.C. PAPER TOWEL DISPENSER - SURFACE MTD
- provided by owner 7. TOILET PAPER DISPENSER - SURFACE MTD - MTD. 1'-7" A.F.F.
- provided by owner
- 8. WALL MOUNTED H.C. LAVATORY MTD. 2'-10" ABOVE FIN. FL. 9. H.C. WATER CLOSET - MTD. 1'-6" ABOVE FINISHED FLOOR
- 10. wall mounted sanitary napkin disposal

STANDARD MOUNTING HEIGHTS SHALL CONFORM TO THE MOST RESTRICTIVE CODE FOR ALL TOILET ACCESSORIES

# CONSTRUCTION NOTES

provide finish floor including all treads and risers typical. repair existing wood sub-floor where damaged or rotted. contractor to notify architect and owner of damaged sub-floor (underlayment) conditions prior to repairs. see specification for floor repair allowance. refer to finish schedule a13 for flooring materials.


- scrape and paint existing toilet partitions. remove and remount partitions to walls.
- 13. provide mtl. guardrail infill panels, see detail x/a14
- provide re-built elevator cab, controls, guiderails and accessories as indicated in specification.
- bid alternate #6 (deduct) thermal drapes. provide light blocking thermal drapery and supports. for (13) type a and a1 windows in meeting rm. 207 see specifications for additional information.
- refurbish and reset existing water closet, see plumbing dwgs. for additional information.
- refurbish and reset existing lavatory, see plumbing dwgs. for additional information.
- provide new lavatory to match adjacent, see plumbing dwgs. for additional information.
- 19. refurbish and reset existing urinal, see plumbing dwgs. provide fiber reinforced plastic panel (3'-0" wide x 4'-0" tall) over gypsum surrounding urinal.
- 20. provide acoustical tile ceiling, support grid, and sound batt insulation above ceiling in all existing joist bays. see spec. and reflected ceiling plans for additional information.
- remove exist. 4'x4' plywood floor patch in toilet 211 and provide new patch flush with adjacent floor under fin. flr. For additional second floor underlayment patching see allowance in spec.
- reLOCATE exist. TOILET ROOM DOOR AND FRAME TO NEW LOCATION SHOWN ON PLAN.

RENOVATIONS TO: GLENBROOK COMMUNITY CENTER 35 CRESCENT STREET STAMFORD, CONNECTICUT 06906

Description: Date: Revised By: AS BUILT 12/30/2005

SECOND FLOOR PLAN

MAY 25, 2004 1/4" = 1'-0"



SYMBOL LEGEND

- EXISTING WALLS TO REMAIN

- EXISTING TO BE REMOVED

- NEW gypsum board/stud wall PARTITIONS

- DOOR NUMBER - SEE DOOR SCHED. ON DWG. a13

- ROOM NUMBER - SEE RM. FIN. SCHED. ON DWG. A13

- DEMOLITION NOTES - SEE DEMO plans a4

1 - PARTITION TYPES - SEE sheet A14

window TYPES - SEE sheet A16

1)— — construction notes — SEE plans A5 through a8

 ELEVATION OR SECTION NUMBER SHEET NUMBER

- PLAN, SECTION, DETAIL, OR ELEV. NUMBER SHEET NUMBER

# GENERAL NOTES

- 1. CONTRACTOR TO FIELD VERIFY ALL EXISTING CONDITIONS & DIMENSIONS
- ALL DIMENSIONS ARE TO OUTSIDE FACE OF BRICK, CONCRETE BLOCK OR GYPSUM BOARD
- 3. ALL H.C. ACCESSIBLE ROOMS TO RECEIVE H.C. SIGNAGE AT DOOR - SEE DOOR SCHEDULE, sheet a12
- 4. FOR NEW WORK BEING DONE ON EXISTING DOORS & FRAMES SEE DOOR SCHEDULE, sheet a12
- 5. SEAL ALL DUCT & PIPE PENETRATIONS THROUGH RATED WALLS WITH SAFING INSULATION — SEE code information sheet
- for LOCATIONS OF ALL FIRE RATED PARTITIONS SEE SPECS. PATCH ALL EXISTING CONCRETE BLOCK WALLS AFFECTED
- BY NEW WORK
- PATCH ALL EXISTING GYPSUM BOARD AND ACOUSTICAL CEILINGS AFFECTED BY NEW WORK
- PATCH ALL EXISTING VCT FLOORING AND RUBBER BASE AFFECTED BY NEW WORK

# CONSTRUCTION NOTES

(1)—

- 1. re-build third floor dormer assembly: which includes but is not limited to, replacing exterior siding, trim, asphalt shingle roofing, flashings, windows, damaged or rotted framing, roof deck, insulation, vapor barrier and all interior finishes. Typical for all 8 dormers. see allowance for dormer framing repairs.
- 2. provide 32"X32" fiberglass shower unit
- 3. re-use exist. toilet door. relocate to north wall
- 4. provide finish floor including all treads and risers typical. repair existing wood sub-floor where damaged or rotted. contractor to notify architect and owner of damaged sub-floor conditions prior to repairs.
  refer to finish schedule a13 for flooring materials.
- provide mtl. guardrail infill panels, see detail x/a14
- provide re-built elevator cab, controls, guiderails and accessories as indicated in specification.
- relocate existing water closet, see plumbing dwgs. for additional information.
- 8. relocate existing lavatory, see plumbing dwgs. for additional information.
- refurbish and reset existing lavatory, see plumbing dwgs. for additional information.
- 10. provide acoustical tile ceiling, support grid, see spec. and reflected ceiling plans for additional information.
- . replacement windows, typical for all third floor windows (BASE BID) see specification and window sheet a16 FOR ADDITIONAL information.
- 12. provide finish floor OVER ACOUSTIC FLOOR MAT ASSEMBLY IN DANCE ROOM 305. SEE SPEC. AND DETAIL 7/A14. PROVIDE 1:8 SLOPE AT DOORS TO MATCH HEIGHT OF ADJACENT FIN. FLRS. repair existing wood sub-floor where damaged or rotted. contractor to notify architect and owner of damaged sub—floor conditions prior to repairs. refer to finish schedule a13 for flooring materials.
- attic space (not a structured attic floor platform) indicated on plan. contractor to provide batt insulation and rafter vent in ea. sloped rafter bay of exist. hip roof for entire attic space. see specification for additional information.
- PROVIDE BLOCKING, INTERIOR/EXTERIOR FINISHES FOR WINDOW INFILL, NEW OPENING AND INSULATED REMOVABLE COVERS FOR (4) WINDOW AC UNITS IN PLACE OF (4) TYPE "B" WINDOWS. AC UNITS PROVIDED BY OWNER. COORDINATE SIZE OF OPENINGS WITH OWNER.

RENOVATIONS TO:

STAMFORD, CONNECTICUT 06906

Project Title:

GLENBROOK COMMUNITY CENTER 35 CRESCENT STREET

project NORTH


third FLOOR PLAN


AS BUILT 12/30/2005


THIRD FLOOR PLAN


Drawing Title:

Drawing Number: MAY 25, 2004 Scale: 1/4" = 1'-0" Drawn By:










# GENERAL NOTES

- 1. FOR ADDITIONAL LIGHTING INFORMATION SEE ELECTRICAL
- FOR ADDITIONAL MECHANICAL INFORMATION SEE
- MECHANICAL DRAWINGS
- 3. FOR SEISMIC BRACING AT ALL A.C.T. SEE DETAIL A/A9 4. FOR CEILING HEIGHTS - SEE ROOM FIN. SCHEDULE
- 5. patch, scrape and paint all e.c.t.r.

# CONSTRUCTION NOTES




- provide NEW ACOUSTICAL CEILING TILES IN HIGH POCKET OF TOILET 212
- PATCH ALL EXISTING GYPSUM CEILINGS AFFECTED BY MECHANICAL, FIRE PROTECTION AND ELECTRICAL WORK

second floor


SCALE: 1/4" = 1'-0"


reflected ceiling PLAN



SECOND FLOOR REFLECTED CEILING PLAN

Drawing Number: MAY 25, 2004 1/4" = 1'-0"Drawn By:





- DRAWINGS
- 2. FOR ADDITIONAL MECHANICAL INFORMATION SEE MECHANICAL DRAWINGS
- 3. FOR SEISMIC BRACING AT ALL A.C.T. SEE DETAIL A/A9
- 4. FOR CEILING HEIGHTS SEE ROOM FIN. SCHEDULE 5. patch, scrape and paint all e.c.t.r.

## 1)— CONSTRUCTION NOTES

- REMOVE EXIST. ACT AND PATCH TOP OF SLOPED CEILING IN KITCHEN WITH |" GYP. BD. ON A 3|" MTL. STUD LEDGER
- PATCH ALL EXISTING GYPSUM CEILINGS AFFECTED BY MECHANICAL, FIRE PROTECTION AND ELECTRICAL WORK TYPICAL

RENOVATIONS TO: GLENBROOK COMMUNITY CENTER 35 CRESCENT STREET STAMFORD, CONNECTICUT 06906

third floor

SCALE: 1/4" = 1'-0"


reflected ceiling PLAN


12/30/2005 AS BUILT


THIRD FLOOR REFLECTED CEILING PLAN


Drawing Title:

Drawing Number: MAY 25, 2004 1/4" = 1'-0"Drawn By:









STAMFORD, CONNECTICUT 06906

- 1. THE INTENT OF THESE CONTRACT DOCUMENTS IS FOR THE CONTRACTOR TO FURNISH AND INSTALL COMPLETE MECHANICAL AND ELECTRICAL SYSTEMS. THESE MECHANICAL AND ELECTRICAL SYSTEMS INCLUDE PLUMBING, FIRE PROTECTION, HVAC, ELECTRICAL AND ALL ASSOCIATED SPECIAL SYSTEMS. ALL SYSTEMS SHALL BE COMPLETE IN ALL RESPECTS. OPERATING, TESTED, ADJUSTED, APPROVED BY THE AUTHORITIES HAVING JURISDICTION AND READY FOR PENETCIAL LISE BY THE COMMENT. FOR BENEFICIAL USE BY THE OWNER.
- 2. THE CONTRACTOR SHALL OBTAIN AND REVIEW ALL CONTRACT DOCUMENTS, INCLUDING PROJECT MANUAL, PLANS AND SPECIFICATIONS OF ALL TRADES BEFORE SUBMITTING BID. REFER TO SPECIFICATIONS, PROJECT MANUAL AND PLANS, INCLUDING ALL EQUIPMENT SCHEDULES FOR MECHANICAL AND ELECTRICAL INFORMATION. CONTRACTOR SHALL WALK THROUGH BUILDING PRIOR TO SUBMITTING BID.
- 3. ALL OF THE CONTRACT DRAWINGS AND SPECIFICATIONS ARE COMPLIMENTARY TO FORM A TOTAL DESIGN PACKAGE. IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR/CONSTRUCTION MANAGER TO DETERMINE WHICH TRADE CONTRACTOR IS RESPONSIBLE FOR VARIOUS PORTIONS OF THE WORK. 4. ALL WORK AND ACTION DEPICTED AND DESCRIBED SHALL BE PERFORMED BY THE CONTRACTOR UNLESS SPECIFICALLY NOTED OTHERWISE.
- 5. PROVIDE SUPPORT/BRACING OF EQUIPMENT AND BUILDING SERVICES FOR SEISMIC RESTRAINT AS REQUIRED BY
- 6. OBTAIN AND PAY FOR ALL REQUIRED PERMITS AND INSPECTIONS.

PERFORMED AT NO ADDITIONAL COST TO THE OWNER.

- ALL EQUIPMENT, MATERIALS AND RELATED SYSTEMS COMPONENTS SHALL BE NEW UNLESS SPECIFICALLY NOTED
  OTHERWISE.
- 8. REPAIR AND/OR REPLACE AT NO COST TO OWNER ALL EQUIPMENT AND MATERIALS DAMAGED DURING
- 9. THE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL ARRANGEMENT OF SYSTEMS AND WORK INCLUDED IN THE CONTRACT. THE CONTRACTOR SHALL COORDINATE LOCATIONS OF EQUIPMENT WITH ALL TRADES BEFORE STARTING CONSTRUCTION. ANY MODIFICATIONS TO THE EQUIPMENT LAYOUT REQUIRED FOR INSTALLATION ARE TO BE
- 10. REFER TO THE ARCHITECTURAL DRAWINGS FOR THE EXACT LOCATION OF LIGHT FIXTURES AND MOUNTING HEIGHTS OF EQUIPMENT. INCLUSIVE OF RECEPTACLES, SWITCHES, THERMOSTATS, ETC. ALL SUCH EQUIPMENT AND COLORS SHALL BE COORDINATED WITH THE ARCHITECT. CONTACT ARCHITECT FOR CLARIFICATION OF MOUNTING
- REQUIREMENTS, IF INFORMATION IS NOT CONTAINED IN THE DRAWINGS. ALL WORK SHALL BE PERFORMED IN COMPLIANCE WITH THE APPLICABLE CODES IN THE ORDINANCES AND THE REGULATORY AGENCIES HAVING JURISDICTION.
- 12. ALL EQUIPMENT SHALL BE LOCATED IN ACCESSIBLE LOCATIONS. WHEN A PIECE OF EQUIPMENT MUST BE LOCATED ABOVE AN INACCESSIBLE CEILING OR WALL THEN THE APPROPRIATE ACCESS DOOR SHALL BE PROVIDED. THESE SHALL BE COORDINATED WITH THE ARCHITECT.
- 13. WHEN CONFLICTS OCCUR BETWEEN THE DRAWINGS AND/OR SPECIFICATIONS IT SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER. THE CONTRACTOR SHALL CARRY AS PART OF THE BID THE LARGER QUANTITY AND/OR MORE EXPENSIVE ITEM(S).
- 14. CONTRACTORS SHALL COORDINATE THEIR WORK WITH ALL OWNER-FURNISHED EQUIPMENT, INCLUDING REQUIRED SERVICE CONNECTIONS, RECEPTACLES, ETC. BEFORE INSTALLTION.
- CONTRACTORS SHALL PROVIDE ALL REQUIRED SLEEVES AND SEALS FOR PIPES OR CONDUIT PENETRATING WALLS OR FLOOR SLABS WITH FIRE STOPPING SEALANT WHERE REQUIRED.
- 16. ALL FLOOR MOUNTED MECHANICAL AND ELECTRICAL EQUIPMENT SHALL BE INSTALLED ON A CONCRETE
- 17. ELECTRICAL CONDUITS & BOXES TO BE CONCEALED IN WALLS OR ABOVE CEILING WHEREVER POSSIBLE. COORDINATE ALL PIPING AND CONDUITS LEAVING THE BUILDING WITH THE SITE CONTRACTOR(S) BEFORE INSTALLATION.
- 19. PROVIDE VIBRATION ISOLATION FOR ALL MECHANICAL EQUIPMENT.
- 20. PROVIDE VIBRATION ISOLATORS FOR ALL PIPING SUPPORTS CONNECTED TO AND WITHIN 50 FEET OF ISOLATED EQUIPMENT THROUGHOUT MECHANICAL EQUIPMENT ROOMS. 21. LOCATE ALL TEMPERATURE, PRESSURE AND FLOW MEASURING DEVICES IN ACCESSIBLE LOCATIONS WITH STRAIGHT
- SECTION OF PIPE OR DUCT UP/DOWN STREAM AS RECOMMENDED BY THE MANUFACTURER FOR GOOD ACCURACY. PROVIDE ACCESS PANELS FOR INSTALLATION IN WALLS AND CEILINGS, WHERE REQURIED, TO SERVICE DAMPERS, VALVES, SMOKE DETECTORS AND OTHER CONCEALED MECHANICAL EQUIPMENT.
- ALL EQUIPMENT, PIPING, DUCT WORK SHALL BE SUPPORTED AS DETAILED, SPECIFIED AND REQUIRED TO PROVIDE A VIBRATION FREE INSTALLATION.
- 24. LOCATION AND SIZES OF ALL FLOOR, WALL AND ROOF PENETRATIONS SHALL BE COORDINATED WITH ALL OTHER TRADES INVOLVED.

- 1. THIS PROJECT IS A RENOVATION OF AN EXISTING FACILITY. IT IS THE INTENT OF THE DEMOLITION DRAWING TO LEAVE ALL MATERIALS OUTSIDE THE LIMITS OF THIS CONTRACT IN EXISTING OPERATING CONDITION.
- BEFORE SUBMITTING HIS BID THE CONTRACTOR SHALL VISIT THE SITE AND BECOME THOROUGHLY FAMILIAR WITH THE EXISTING CONDITIONS UNDER WHICH THE PROJECT IS TO BE COMPLETED.
- 3. THE CONTRACTOR SHALL BE HELD RESPONSIBLE FOR ANY ASSUMPTIONS, OMISSIONS OR ERRORS HE MAKES AS A RESULT ON HIS FAILURE TO BECOME FULLY FAMILIAR WITH THE EXISTING CONDITIONS.
- 4. IT IS NOT THE INTENT OF THESE DRAWINGS TO SHOW EVERY PIECE OF EQUIPMENT, PIPING OR CONDUIT TO BE REMOVED. EQUIPMENT NOT BEING USED SHALL BE REMOVED INCLUDING ALL ASSOCIATED HANGERS, SUPPORTS, PIPES, DUCTS, CONDUITS, WIRES AND CONTROLS BACK TO THE POINT OF ORIGIN.
- 5. NO EQUIPMENT, PIPING OR CONDUIT SHALL BE ABANDONED IN PLACE UNLESS SPECIFICALLY NOTED. PROPERLY DISPOSE OF ALL DEMOLISHED EQUIPMENT AND MATERIALS IN COMPLIANCE WITH CODES AND REGULATIONS.
- 7. RELOCATE EXISTING EQUIPMENT, PIPING, WIRING AND RELATED SYSTEMS TO REMAIN AS REQUIRED FOR CONSTRUCTION. EXTEND FEEDER/CONDUIT AND PROVIDE RECONNECTIONS FOR SYSTEM TO BE FULLY OPERATIONAL. ALL RELOCATED EQUIPMENT SHALL BE PROTECTED DURING CONSTRUCTION.
- 8. PROVIDE TEMPORARY CONNECTIONS AND SYSTEM MODIFICATIONS AS REQUIRED FOR CONSTRUCTION.
- 9. INCLUDE ALL WORK REQUIRED TO ALLOW PHASED CONSTRUCTION WHERE NECESSARY. COORDINATE WITH GENERAL CONTRACTOR/CONSTRUCTION MANAGER FOR PHASING REQUIREMENTS.
- ON WALLS AND CEILINGS TO BE DEMOLISHED SHALL BE REMOVED UNLESS OTHERWISE SPECIFIED. FIELD VERIFIED FOR EXACT LOCATIONS AND QUANTITY OF ITEMS BEING REMOVED. COORDINATE WITH ARCHITECTURAL PLANS FOR SCOPE AREA OF DEMOLITION AND CONSTRUCTION.
- 11. GENERAL CONTRACTOR IS RESPONSIBLE OF PATCHING, REPAIRING, CAPPING, ETC. PER DEMOLITION AND
- 12. REBALANCE EXISTING AIR AND WATER SYSTEMS ASSOCIATED WITH RENOVATIONS, INCLUDING ALL RENOVATED AREAS AND ALL AREAS AFFECTED BY SYSTEM MODIFICATIONS.

- 1. IT IS NOT THE INTENT OF THE DRAWINGS TO SHOW INDIVIDUAL BRANCH PIPING TO EACH PLUMBING FIXTURE: ONLY BRANCH PIPING TO GROUPS OF FIXTURES IS INDICATED. EACH AND EVERY FIXTURE SHALL BE PROPERLY PIPED TO WATER, WASTE AND VENT PIPING SYSTEMS. FOR INDIVIDUAL PIPE SIZES TO EACH FIXTURE, REFER TO THE
- 2. PIPING LAYOUTS AS INDICATED ON THE DRAWINGS ARE DIAGRAMATIC: PROVIDE ADDITIONAL FITTINGS AND OFFSETS AS REQUIRED FOR COORDINATION WITH BUILDING CONSTRUCTION AND THE WORK OF OTHER TRADES.
- 3. PROVIDE CONDENSATE DRAINS FOR ALL COOLING COILS; PIPE BY GRAVITY TO INDIRECT WASTE OR IF GRAVITY DRAINAGE IS NOT POSSIBLE. PROVIDE A CONDENSATE REMOVAL PUMP, WIRED TO LOCAL POWER CIRCUIT AND PIPED TO INDIRECT WASTE.
- 4. COORDINATE MOUNTING HEIGHTS OF PLUMBING FIXTURES WITH ARCHITECTURAL DRAWINGS. 5. PROVIDE SHUT OFF VALVES IN ALL DOMESTIC WATER PIPING SYSTEM BRANCHES IN WHICH BRANCH PIPING SERVES TWO OR MORE FIXTURES.
- 6. ALL PIPING SHALL GRADE TO LOW POINTS. PROVIDE HOSE AND DRAIN VALVES AT THE BOTTOM OF ALL RISERS AND LOW POINTS.
- 7. UNIONS AND/OR FLANGES SHALL BE INSTALLED AT EACH PIECE OF EQUIPMENT, IN BYPASSES AND IN LONG PIPING RUNS (100 FEET OR MORE) TO PERMIT DISASSEMBLY FOR ALTERATION AND REPAIRS.
- 8. PROVIDE ALL PLUMBING FIXTURES AND EQUIPMENT WITH ACCESSIBLE STOPS. 9. INSTALL PIPING SO THAT ALL VALVES, STRAINERS, UNIONS, TRAPS, FLANGES AND OTHER APPURTENANCES
- 10. PROVIDE CLEANOUTS IN SANITARY DRAINAGE SYSTEM AT ENDS OF RUNS, AT CHANGES IN DIRECTION, NEAR THE BASE OF STACKS, EVERY 50 FEET IN HORIZONTAL RUNS AND ELSEWHERE AS INDICATED.
- 11. ALL CLEANOUTS SHALL BE FULL SIZE OF PIPE FOR PIPE 6 INCHES AND SMALLER AND SHALL BE 6 INCHES FOR PIPE SIZES LARGER THAN 6 INCHES.
- 12. ALL PIPING WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.
- 13. PROVIDE FLEXIBLE CONNECTIONS IN ALL PIPING SYSTEMS CONNECTED TO PUMPS AND OTHER EQUIPMENT WHICH REQUIRED VIBRATION ISOLATION, EXCEPT WATER COILS. FLEXIBLE CONNECTIONS SHALL BE PROVIDED AS CLOSE TO THE EQUIPMENT AS POSSIBLE.

- 1. PIPING AND DUCT WORK LAYOUTS AS INDICATED ON THE DRAWINGS ARE DIAGRAMATIC; PROVIDE ADDITIONAL TRANSITIONS AND OFFSETS AS REQUIRED FOR COORDINATION WITH BUILDING CONSTRUCTION AND THE WORK OF COURSE TRANSE.
- 2. PROVIDE VOLUME DAMPERS, THROTTLING VALVES AND ISOLATION VALVES AS SPECIFIED AND AS INDICATED ON THE
- 3. PROVIDE FIRE DAMPERS AT DUCT PENETRATIONS OF FIRE RATED PARTITIONS
- 4. THE AUTOMATIC TEMPERATURE CONTROL SYSTEM SHALL BE COMPLETE IN ALL REGARDS, TESTED AND CAPABLE OF ACHIEVING THE SEQUENCES OF OPERATION. ALL DEVICES SHALL BE UNDER SYSTEM CONTROL. ALL ZONES SHALL BE THERMOSTATICALLY CONTROLLED WHETHER OR NOT A THERMOSTAT, SENSOR OR CONTROLLER IS INDICATED.
- 6. FLEX DUCT RUNS SHALL NOT BE LONGER THAN 5 FT. 7. PROVIDE VOLUME DAMPERS AT ALL SUPPLY DIFFUSERS, OUTSIDE AIR INTAKE AND RELIEF DUCTS AND EXHAUST

5. MAINTAIN MANUFACTURER'S RECOMMENDED MINIMUM CLEARANCES FOR INSTALLATION OF EQUIPMENT.

- 8. PROVIDE VANDAL RESITANT COVERS FOR ALL THERMOSTATS.
- 9. ALL DUCTWORK DIMENSIONS, AS SHOWN ON THE DRAWINGS, ARE INTERNAL CLEAR DIMENSIONS AND DUCT SIZE SHALL BE INCREASED TO COMPENSATE FOR DUCT LINING THICKNESS.
- COORDINATE DIFFUSER, REGISTER AND GRILLE LOCATIONS WITH ARCHITECTURAL REFLECTED CEILING PLANS, LIGHTING AND OTHER CEILING ITEMS.
- 11. FINNED TUBE RADIATION ENCLOSURES SHALL BE WALL TO WALL UNLES OTHERWISE NOTED.
- 12. PROVIDE FLEXIBLE CONNECTIONS IN ALL DUCTWORK SYSTEMS CONNECTED TO AIR HANDLING UNITS, FANS AND OTHER EQUIPMENT WHICH REQUIRE VIBRATION ISOLATION. FLEXIBLE CONNECTIONS SHALL BE AT THE POINT OF CONNECTION TO THE EQUIPMENT UNLESS OTHERWISE INDICATED
- 13. ALL DUCTWORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN DUCTS, INCLUDING DIVIDED DUCTS AND TRANSITIONS AROUND OBSTRUCTIONS, SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.
- 14. PROVIDE ACCESS DOORS IN DUCTWORK TO PROVIDE ACCESS FOR ALL SMOKE DETECTORS, FIRE DAMPERS, SMOKE DAMPERS, VOLUME DAMPERS, COILS AND OTHER ITEMS LOCATED IN DUCTWORK WHICH REQUIRE SERVICE OR
- PROVIDE ACCESS DOORS IN DUCTWORK FOR OPERATION, ADJUSTMENT AND MAINTENANCE OF ALL FANS, VALVES AND MECHANICAL EQUIPMENT.

## 16. PROVIDE FLEXIBLE DUCT CONNECTIONS TO ALL MECHANICAL AIR MOVING DEVICES.

- 1. UNLESS OTHERWISE NOTED, ALL PIPING IS OVERHEAD, TIGHT TO UNDERSIDE OF STRUCTURE OR SLAB, WITH SPACE
- INSTALL PIPING SO THAT ALL VALVES, STRAINERS, UNIONS, TRAPS, FLANGES AND OTHER APPURTENANCES REQUIRING ACCESS ARE ACCESSIBLE.
- 3. UNIONS AND/OR FLANGES SHALL BE INSTALLED AT EACH PIECE OF EQUIPMENT, IN BYPASSES AND IN LONG PIPING RUNS (100 FEET OR MORE) TO PERMIT DISASSEMBLY FOR ALTERATION AND REPAIRS.
- 4. ALL PIPING WORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED. OFFSETS IN PIPING AROUND OBSTRUCTIONS SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.
- 5. PROVIDE FLEXIBLE CONNECTIONS IN ALL PIPING SYSTEMS CONNECTED TO PUMPS AND OTHER EQUIPMENT WHICH REQUIRED VIBRATION ISOLATION, EXCEPT WATER COILS. FLEXIBLE CONNECTIONS SHALL BE PROVIDED AS CLOSE TO THE EQUIPMENT AS POSSIBLE.

ADDITIONAL LOCATIONS AND INFORMATION.

- CONTRACTOR SHALL COORDINATE THE LOCATION AND QUANTITY OF ALL MECHANICAL EQUIPMENT WITH THE
  MECHANICAL CONTRACTOR. PROVIDE POWER WIRING FOR ALL EQUIPMENT. REFER TO MECHANICAL DRAWINGS FOR
  MECHANICAL CONTRACTOR. IN INSCRIPTION.
- 2. ALL FIXTURES SHALL BE SUPPORTED INDEPENDENTLY OF THE FINISHED CEILING/STRUCTURE AND SHALL BE SEISMICALLY SUPPORTED AS REQUIRED BY CODE AND THE AUTHORITY HAVING JURISDICTION.
- ALL BRANCH CIRCUIT WIRING SHOWN IS DIAGRAMMATIC. EXACT ROUTING SHALL BE FIELD COORDINATED TO CLEAR THE WORK OF OTHER TRADES.
- IT IS NOT THE INTENTION TO SHOW EVERY FITTING, HANGER, WIRE OR DEVICE. ALL SUCH ITEMS SHALL BE FURNISHED AND INSTALLED AS NECESSARY FOR A COMPLETE SYSTEM. 5. ALL RECEPTACLES LOCATED WITHIN 6' OF SINKS AND ALL WET LOCATIONS SHALL BE GFI TYPE.
- 6. PROVIDE POWER FED FROM PANEL WITH SUFFICIENT CAPACITY AND SPACE FOR ALL MISCELLANEOUS SYSTEMS.
  THESE SYSTEMS SHALL INCLUDE, BUT ARE NOT LIMITED TO, MONITORING SYSTEMS, CONTROL PANEL, ANNUNCIATOR
  PANELS, PLUMBING ACCESSORIES, ETC. CONTRACTOR SHALL FURNISH AND INSTALL ALL BRANCH CIRCUIT WIRING
- AND CIRCUIT BREAKERS FOR ALL EQUIPMENT SHOWN AS REQUIRED. 7. ALL SWITCHES, RECEPTACLES AND EQUIPMENT SHALL BE PROPERLY LABELED.
- 8. CONTRACTOR SHALL DETERMINE THE QUANTITY OF CONDUCTORS REQUIRED FOR PROPER OPERATION OF ALL SWITCHING SCHEMES. NO CONDUIT SHALL BE ALLOWED IN CONCRETE SLABS, UNLESS SPECIFICALLY APPROVED BY THE STRUCTURAL ENGINEER.
- 10. LABEL ALL UNUSED BREAKERS AS SPARE AND TRIP TO THE OFF POSITION. 11. ELECTRICAL DEMOLITION TO BE SUPERVISED BY LICENSED ELECTRICAL CONTRACTOR. EACH CIRCUIT TO BE VERIFIED
- "COLD" & DISCONNECTED FROM ELECTRICAL SERVICE PRIOR TO COMMENCING REMOVAL. 12. VERIFY & COORDINATE ALL ELECTRICAL DEVICES BEING REMOVED FOR DISCONNECTING FEED AND REMOVING ASSOCIATED WIRING AND CONDUIT BACK TO PANELBOARD OR SOURCE.
- 13. WHERE ELECTRICAL EQUIPMENT & DEVICES ARE BEING REMOVED, COORDINATE AND FIELD VERIFY IF BRANCH CIRCUIT FEEDS THRU EQUIPMENT/DEVICE BEING REMOVE TO EQUIPMENT/DEVICE TO REMAIN. BRANCH CIRCUITS SHALL BE SPLICED OR RELOCATED TO MAINTAIN CONTINUATION OF SERVICES.
- ALL EXISTING PANELBOARD DIRECTORIES SHALL BE UPDATED TO INCLUDE ALL EXISTING, ALL NEW, AND ALL SPARE CIRCUITS.
- 15. WHERE EXISTING DEVICES ARE REMOVED & NO NEW DEVICES ARE INSTALLED IN THE SAME LOCATION, REMOVE ALL WIRING FROM BOX & PROVIDE PROPERLY SIZED BLANK COVER PLATE.
- 16. ALL REMOVED COMPONENTS SHALL BE LEGALLY DISPOSED OF BY CONTRACTOR UNLESS SPECIFICALLY NOTED 17. COORDINATE WITH ALL OWNERS POWER EQUIPMENT TO REMAIN. PROVIDE NEW CONDUIT, RECEPTACLE AND/OR
- TELE/DATA AT NEW LOCATION(S). USE SPARE BREAKERS IN PANELBOARDS.
- 18. ALL DEVICE COLORS SHALL BE COORDINATED WITH ARCHITECT BEFORE PURCHASING. 19. ALL FIXTURES SHADED ON THE DIAGONAL SHALL HAVE AN INTERNAL BATTERY BACKUP BALLAST AS MANUFACTURED BY BODINE OR EQUIVALENT. THE BALLAST SHALL MONITOR THE CIRCUIT AHEAD OF ANY SWITCHES.
- 20. ALL EXIT SIGNS, EMERGENCY LIGHTS AND NIGHT LIGHTS SHALL BE WIRED TO THE ROOM LIGHTING BRANCH CIRCUIT AHEAD OF ANY SWITCHES.
- CONTRACTOR SHALL COORDINATE THE LOCATION OF ALL DUCT SMOKE WITH THE MECHANICAL CONTRACTOR, ALL
  DEVICES SHALL BE WIRED TO THE FIRE ALARM SYSTEM.

22. CONTRACTOR SHALL COORDINATE THE LOCATION AND QUANTITY OF ALL SPRINKLER SYSTEM TAMPER, FLOW AND PRESSURE SWITCHES WITH THE SPRINKLER CONTRACTOR. WIRE ALL THE DEVICES TO THE FIRE ALARM SYSTEM.

- THIS CONTRACT INCLUDES A PERFORMANCE SPECIFICATION FOR THE ENTIRE FIRE PROTECTION SYSTEM. PROVIDE ALL PIPING, SUPPORT AND EQUIPMENT FOR A COMPLETE FULL COVERAGE SYSTEM IN CONFORMANCE WITH NFPA, STATE AND LOCAL CODES. THE OWNER'S INSURAANCE COMPANY AND THE AUTHORITY HAVING JURISDICTION.
- SPRINKLER HEAD LOCATIONS ARE SHOWN ON THE CONTRACT DOCUMENTS THEY ARE INDICATED FOR GENERAL
  COORDINATION PURPOSES ONLY AND DO NOT RELIEVE THE CONTRACTOR FROM FULL COMPLIANCE WITH THE
  APPLICABLE CODES AND AUTHORITIES. CONTRACTOR SHALL COORDINATE SPRINKLER HEAD LOCATIONS WITH THE
  LATEST ARCHITECTURAL REFLECTED CEILING PLANS AS REQUIRED.
- 3. PIPING LAYOUTS AS INDICATED ON DRAWINGS ARE DIAGRAMATIC: PROVIDE ADDITIONAL FITTINGS AND OFFSETS AS REQUIRED FOR COORDINATION WITH BUILDING CONSTRUCTION AND THE WORK OF OTHER TRADES.

- 1. WORK SHALL BE PHASED TO ALLOW OWNER TO CONTINUE BUSINESS OPERATIONS DURING THE CONSTRUCTION PERIOD. COORDINATE WORK WITH OWNER AND GENERAL CONTRACTOR TO ALLOW SUFFICIENT TIME TO RELOCATE OPERATIONS WITHIN THE BUILDING PRIOR TO COMMENCING WORK IN AREAS AFFECTED BY DEMOLITION OR NEW
- 2. WORK REQUIRING INTERRUPTION OF ESSENTIAL BUILDING SERVICES SHALL BE PERFORMED DURING UNOCCUPIED PERIODS (AFTER BUSINESS HOURS), ESSENTIAL SERVICES SHALL INCLUDE BUT NOT BE LIMITED TO VENTILATION, WATER AND SEWER SERVICE, POWER, TELECOMMUNICATIONS. HEATING AND AIR CONDITIONING SHALL BE CONSIDERED TO BE ESSENTIAL WHEN CONDITIONS WILL CAUSE TEMPERATURES IN THE BUILDING TO FALL BELOW SETEONE SYSTEMS.

	PLUMBING ABBREVIATIONS (NOT ALL SYMBOLS ARE USED)						
AFF C CO CW DF EWC FD HW HWR	ABOVE FINISHED FLOOR CONDENSATE CLEANOUT COLD WATER DRINKING FOUNTAIN ELECTRIC WATER COOLER FLOOR DRAIN FEET HOT WATER HOT WATER LAVATORY	S RWL UR V VTR W WC WCO WHA	SANITARY WASTE RAINWATER LEADER URINAL VENT VENT THRU ROOF WASTE WATER CLOSET WALL CLEAN OUT WATER HAMMER ARRESTOR				

	MECHANICAL LEGEND (NOT ALL SYMBOLS ARE USED)									
	RECTANGULAR, FLAT OVAL OR ROUND AIR DUCT (PLAN VIEW)  SUPPLY OR OUTSIDE AIR DUCT UP OR CSD SUPPLY OR OUTSIDE AIR DUCT DOWN  RETURN OR EXHAUST AIR UP OR CRG/CRR RETURN OR EXHAUST DUCT DOWN  MOTORIZED DAMPER	PIPE ELBOW UP  PIPE ELBOW DOWN  TAKEOFF FROM TOP OF MAIN PIPE  TAKEOFF FROM BOTTOM OF MAIN PIPE  ACCORDANCE  TAKEOFF FROM BOTTOM OF MAIN PIPE  DIRECTION OF SUPPLY OR OUTSIDE AIR  DIRECTION OF RETURN OR EXHAUST AIR								
<b>V</b> D →	VOLUME DAMPER	THERMOSTAT OR TEMPERATURE SENSOR  OR "ER" EXISTING TO BE REMOVED  OR "ER" EXISTING TO REMAIN								
<u> </u>	TURNING VANES	ERL EXISTING TO BE RELOCATED								
	SQUARE TO ROUND DUCT TRANSITION DUCT SMOKE DETECTOR	FLEXIBLE DUCT WORK								
(H)	HUMIDITY SENSOR HUMIDISTAT	S—S CONTROL VALVE								
>— ° —	CONDENSATE  CARBON MONOXIDE DETECTOR	FD—— FIRE DAMPER  FLEX CONNECTION								

	MECHANICAL AB	BREVIA	TIONS						
	(NOT ALL SYMBOLS ARE USED)								
AFF C CA CER CHWR CHWS CO CR CU CSD CW EAT EG ESP FCU FOS FOR G	ABOVE FINISHED FLOOR CONDENSATE COMPRESSED AIR CEILING EXHAUST REGISTER CUBIC FEET PER MINUTE CHILLED WATER RETURN CHILLED WATER SUPPLY CLEANOUT STEAM CONDENSATE RETURN CONDENSING UNIT CEILING SUPPLY DIFFUSER COLD WATER ENTERING AIR TEMPERATURE EXHAUST FAN EXHAUST GRILLE	HW HWR HWS MAX MBH MIN NTS OA OBD RA RG REF RIH RTU SA SAN SP SPRK SS T'STAT	MAXIMUM BTU PER HOUR (THOUSAND) MINIMUM NOT TO SCALE OUTSIDE AIR OPPOSED BLADE DAMPER RETURN AIR RETURN GRILLE ROOF EXHAUST FAN ROOF INTAKE HOOD ROOF TOP UNIT SUPPLY AIR						
GPF GPH	GALLONS PER FLUSH GALLONS PER HOUR	V VAC	VOLT VACUUM						
GPM HP	GALLONS PER MINUTE HORSEPOWER	VAC	VOLUME DAMPER						


RENOVATIONS TO:


GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET STAMFORD, CONNECTICUT 06906 AS BUILT 1/4/2006

GENERAL NOTES AND LEGENDS

MAY 25, 2004 1/4" = 1'-0" Project Number:





RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET
STAMFORD, CONNECTICUT 06906

Revision: Date: Revised By:

AS BUILT 1/04/2006

SECOND FLOOR MECHANICAL PLAN Date:


MAY 25, 2004

Scale:

1/4" = 1'-0"

Drawn By:

Project Number:





RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET
STAMFORD, CONNECTICUT 06906

Revision: Description: Date: Revised By:

AS BUILT 1/04/2006

THIRD FLOOR MECHANICAL PLAN

Drawing Title:

Date:


MAY 25, 2004

Scale:

1/4" = 1'-0"


Drawn By:

Project Number:




UNIT VENTILATOR/RADIATION DETAIL

NOT TO SCALE




BELL MOUTH TAKEOFF DETAIL NOT TO SCALE



# RECTANGULAR BELL MOUTH TAKEOFF DETAIL


NOT TO SCALE




- PROVIDE LONGITUDINAL AND LATERAL BRACING ON PIPING 2 1/2" AND GREATER, GAS PIPING 1" I.D. AND GREATER AND PIPING IN BOILER AND MECHANICAL ROOMS 1 1/4" AND GREATER, WHERE SUSPENDED 12" OR MORE FROM SUPPORTING STRUCTURE.
- 2. PROVIDE SIMILAR BRACING ON ALL DUCTWORK WITH CROSS-SECTIONAL AREA OF 6 SF OR GREATER OR DIAMETER OF 28 IN. OR GREATER WHERE SUSPENDED 12" OR MORE FROM SUPORTING STRUCTURE.
- MAKE END CONNECTIONS TO EXISTING STRUCTURAL STEEL WITH 1/2" BOLTS OR TO CONCRETE DECK PER CONNECTION TO CONCRETE DETAIL ABOVE.

PIPE SUPPORT DETAIL

NOT TO SCALE




- 1. PROVIDE BORDER FOR LAY-IN OR SURFACE MOUNT AS REQUIRED.
- 2. DUCT RUNOUTS SHALL BE AS INDICATED ON PLAN. 3. AIR PATTERN INDICATED ON PLAN.
- DIFFUSER LEGEND: TAG PATTERN:




LEGEND: TAG OPATTERN ON RETURN GRILLES NO PATTERN ON SIDEWALL GRILLES

4. PROVIDE MFGR'S SQUARE TO ROUND TRANSITION FOR DIFFUSERS, FLEX DUCT SHALL NOT EXCEED 5'. PROVIDE 2" PLENUM & DUCT CONNECTION BEHIND RETURNS UNLESS OTHERWISE NOTED.




ROOF EXHAUST FAN DETAIL NOT TO SCALE




HOT WATER COIL PIPING

NOT TO SCALE



NOT TO SCALE TRIPLE DUTY VALVE BALL VALVE BALL VALVE FROM HEAT EXCH. STRAINER

IN-LINE PUMP DETAIL NOT TO SCALE



WATER UNIT HEATER PIPING DETAIL NOT TO SCALE

HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 22"X22", 54.6 MBH, 5.6 GPM

EQUIPMENT SCHEDULE

BASEMENT OFFICE

TRANE VUV125 VERTICAL UNIT VENTILATOR WITH HOT WATER COIL/DX COIL

SC/TC: 21.2 MBH/28.7 MBH HEATING: 3.32 GPM, 1.67 FT WPD, 66.45 MBH VUV: 120V/1ø, MCA: 4.00 A

CU: 208C/1ø, MCA: 18 A, MOCP: 30 A PROVIDE WITH DISCONNECT, SUBBASE, 6" FALSE BACK, HYDRONIC COIL DRAIN PAIN, FREEZE STAT, FRESH AIR AND RETURN AIR DAMPERS. PROVIDE 7 DAY, PROGRAMMABLE, NIGHT SETBACK THERMOSTAT.

TRANE TWE048 AIR HANDLING UNIT WITH TTB048 CONDENSING UNIT 1600 CFM SA, 500 CFM OA, AT 0.53" WG SC/TC: 31.5 MBH/46.6 MBH

> AHU: 208V/1ø, 1/2 HP CU: 208V/3ø, MCA: 30 A, MOCP: 50 A PROVIDE FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL

AHU-5, CU-7 CLASSROOM 104 TRANE TWE048 AIR HANDLING UNIT WITH TTB048 CONDENSING UNIT 1600 CFM SA, 500 CFM OA, AT 0.53" WG

SC/TC: 31.5 MBH/46.6 MBH HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 22"X22", 54.6 MBH, 5.6 GPM

AHU: 208V/1ø, 1/2 HP CU: 208V/3ø, MCA: 30 A, MOCP: 50 A PROVIDE FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL

AHU-2, CU-4 SECOND FLOOR RE AL TRANE TWE060 AIR HANDLING UNIT WITH TTB060 CONDENSING UNIT 2000 CFM SA, 440 CFM OA, AT 0.60" WG

SC/TC: 40.7 MBH/60.0 MBH HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 24"X24", 61 MBH. 6.2 GPM AHU: 208V/1ø, 3/4 HP

CU: 208V/1ø, MCA: 38 A, MOCP: 60 A PROVIDE FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL RESISTANT COVER.

TRANE TWE090B1 DUAL CIRCUIT AIR HANDLING UNIT WITH (2) TTB042 CONDENSING UNITS SECOND FLOOR MEETING ROOM 3000 CFM SA, 600 CFM OA, AT 0.7" WG SC/TC: 27.9 MBH/41.5 MBH

HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 36"X24", 83 MBH, 8.4 GPM AHU: 208V/1ø. 1.5 HP CU: 208V/1ø, MCA: 28 A, MOCP: 45 A PROVIDE AIR HANDLING UNIT WITH SPLIT FACE COIL AND DUAL REFRIGERANT CIRCUIT. PROVIDE

FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL RESISTANT COVER. AHU-6, CU-5,8 TRANE TWE090B1 DUAL CIRCUIT AIR HANDLING UNIT WITH (2) TTB042 CONDENSING UNITS THIRD FLOOR DANCE/MUSIC 3000 CFM SA, 600 CFM OA, AT 0.7" WG

HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 36"X24", 83 MBH, 8.4 GPM AHU: 208V/1ø, 1.5 HP CU: 208V/1ø, MCA: 28 A, MOCP: 45 A

PROVIDE AIR HANDLING UNIT WITH SPLIT FACE COIL AND DUAL REFRIGERANT CIRCUIT. PROVIDE FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL RESISTANT COVER.

AHU-3, CU-9 THIRD FLOOR OFFICES TRANE TWE060 AIR HANDLING UNIT WITH TTB060 CONDENSING UNIT 2000 CFM SA, 440 CFM OA, AT 0.60" WG SC/TC: 40.7 MBH/60.0 MBH

SC/TC: 27.9 MBH/41.5 MBH

HOT WATER COIL: 0.25" WG PRESSURE DROP MAX, 500 FPM, 24"X24", 61 MBH. 6.2 GPM AHU: 208V/1ø, 3/4 HP CU: 208V/1ø, MCA: 38 A, MOCP: 60 A

PROVIDE FREEZESTAT, 7 DAY PROGRAMMABLE, NIGHT SETBACK THERMOSTAT WITH VANDAL RESISTANT COVER. PROVIDE DIRECT EXPANSION VALVES, LIQUID LINE RECEIVER AND CHECK VALVE FOR EXTENDED ALL CONDENSING UNITS:

RUN OF REFRIGERANT PIPING. CONFIRM REQUIREMENTS FOR REFRIGERANT PIPING WIWTH THIRD FLOOR OFFICES MANUFACTURER SPECIFIED. COOK 20XLW BELT DRIVEN LOW PRESSURE WALL EXHAUST FAN

2600 CFM AT 0.250" WG 115V/1ø, 1/3 HP PROVIDE WITH WALL COLLAR, OSHA WIRE GUARD, WEATHER HOOD, GRAVITY BACKDRAFT DAMPER AND DAMPER GUARD.

COOK 100C3B CENTRIFUGAL ROOF EXHAUST FAN GANG BATHROOM 900 CFM AT 0.500" WG

115V/1ø. 1/4 HP PROVIDE WITH ROOF CURB, HINGED BASE KIT, MOTORIZED BACKDRAFT DAMPER AND DISCONNECT.

COOK 100SQN-D INLINE EXHAUST FAN 2ND FLOOR BATHROOM

GYM EXHAUST

P-1:

UH-1:

Drawing Title:

225 CFM AT 3/4" WG 115V/1ø, 1/2 HP PROVIDE WITH VARI-SPEED CONTROLLER, FLEX DUCT CONNECTOR, BACKDRAFT DAMPER AND

COOK 60C3B ACE CENTRIFUGAL ROOF EXHAUST FAN THIRD FLOOR BATHROOM

150 CFM AT 3/4" WG 115V/1ø, 1/4 HP PROVIDE WITH PITCHED ROOF CURB (COORDINATE PITCH WITH ARCHITECT), BACKDRAFT DAMPER

AND DISCONNECT. EF-5 COMBUSTION AIR FAN COOK 100SQN-D INLINE EXHAUST FAN

385 CFM AT 3/4" WG 115V/1ø, 1/2 HP PROVIDE WITH VARI-SPEED CONTROLLER, FLEX DUCT CONNECTOR, BACKDRAFT DAMPER, MOTOR COVER, BELT GUARD AND DISCONNECT. INTERLOCK WITH BOILER.

COOK GC-140 CEILING MOUNTED FAN BATHROOM EXHAUST FAN 150 CFM AT 0.50" WG

115V/1ø, 70 WATTS PROVIDE WITH BACKDRAFT DAMPER. HANGING ISOLATOR KIT. ALUMINUM GRILLE, AND UNIT FILTER.

GIV-1

GREENHECK FABRAHOOD GRAVITY INTAKE VENTILATOR 3000 CFM, 30X30 THROAT SIZE, 38X38 CURB CAP PROVIDE WITH BACKDRAFT DAMPER, INSECT SCREEN AND PITCHED ROOF CURB. COORDINATE ROOF CURB DIMENSIONS IN FIELD.

GREENHECK FABRAHOOD GRAVITY INTAKE VENTILATOR 500 CFM, 12X12 THROAT SIZE, 20X20 CURB CAP PROVIDE WITH BACKDRAFT DAMPER, INSECT SCREEN AND PITCHED ROOF CURB. COORDINATE ROOF CURB DIMENSIONS IN FIELD. GIV-2

GREENHECK FABRAHOOD GRAVITY RELIEF VENTILATOR GRV-1 3000 CFM, 30X42 THROAT SIZE, 38X50 CURB CAP
PROVIDE WITH BACKDRAFT DAMPER, INSECT SCREEN AND PITCHED
ROOF CURB. COORDINATE ROOF CURB DIMENSIONS IN FIELD.

VULCAN STYLE DS (INVERTED) FINNED TUBE RADIATION FT-1 3 LINEAR FEET, 12" DEPTH, STEEL 4-1/4" FIN, 40 FINS/FT, 1 ROW,

REFER TO ARCHITECTURAL DRAWINGS. ARCHITECT WILL SPECIFY. SIZE AS INDICATED ON PLANS. OUTSIDE AIR LOUVERS: PROVIDE WITH INSECT SCREENS AND BACKDRAFT DAMPERS. BELL AND GOSSETT SERIES 60 INLINE PUMP MODEL 2X2X7 94 GPM AT 37 FT WG  $\,$ 

208V/3ø, 2 HP, 1750 RPM VULCAN HORIZONTAL UNIT HEATER MODEL HV-118A

18.4 MBH, 1.9 GPM, LAT: 94°F, 500 CFM 115V/1ø, 1/50 HP PROVIDE INTEGRAL THERMOSTAT.

PROVIDE VANDAL RESISTANT COVERS FOR ALL THERMOSTATS, NEW AND EXISTING, THROUGHOUT BUILDING. PROVIDE BIRDSCREENS FOR ALL EXTERIOR LOUVERS AND GRAVITY

HONEYWELL THERMOSTATIC RADIATOR ACTUATOR AND VALVE 3/4", 5.8 GPM CAPACITY


Project Title: RENOVATIONS TO: GLENBROOK COMMUNITY CENTER 35 CRESCENT STREET


STAMFORD, CONNECTICUT 06906


Revision: Revised By: 1/04/2006 AS BUILT

MECHANICAL SCHEDULES AND DETAILS

Drawing Number: MAY 25, 2004 1/4" = 1'-0" Drawn By: Project Number:







PLAN NOTES


- EXISTING WATER CLOSET (WC) REPLACE EXISTING FLOOR FLANGE GASKET, TOILET SEAT AND FLUSH VALVE. REFER TO THE PLUMBING FIXTURE SCHEDULE.
- 2. EXISTING URINAL (UR) REPLACE EXISTING FLUSH VALVE WITH NEW FLUSH VALVE ASSEMBLY. REFER TO THE PLUMBING FIXTURE SCHEDULE.
- EXISTING LAVATORY (LAV) REPLACE EXISTING FAUCET SET AND TRIM WITH 3. NEW FAUCET SET, WATER SUPPLIES/STOPS AND P-TRAP. REFER TO THE PLUMBING FIXTURE SCHEDULE.
- DISCONNECT AND REMOVE EXISTING BROKEN LAVATORY AND RELATED TRIM.

  4. PROVIDE NEW LAVATORY AND FAUCET, WITH NEW WATER SUPPLIES / STOPS AND P-TRAP. CONNECT TO EXISTING WATER AND DRAIN PIPING.
- DISCONNECT AND REMOVE EXISTING WALL MOUNTED DRINKING FOUNTAIN.
  MODIFY EXISTING WATER AND DRAIN PIPING IN WALL AS REQUIRED TO
  5. INSTALL NEW HANDICAP ACCESSIBLE DRINKING FOUNTAIN. PATCH WALL AND
  WALL FINISH DUE TO FOUNTAIN REPLACEMENT.
- EXISTING SANITARY DRAIN AND WATER SUPPLY PIPING FOR THIRD FLOOR PLUMBING FIXTURES LOCATED ABOVE THE SECOND FLOOR CEILING. FIELD VERIFY EXISTING PIPING ABOVE CEILING.
- 6. DISCONNECT AND REMOVE EXISTING SANITARY DRAIN PIPING TO EXISTING THIRD FLOOR WOMEN'S WATER CLOSETS (2). REPIPE EXISTING SANITARY DRAIN TO NEW WATER CLOSET LOCATION (THIRD FLOOR) ABOVE SECOND FLR CEILING.
- $^{7.}$  DISCONNECT AND REMOVE EXISTING SANITARY DRAIN TO EXISTING THIRD FLOOR MEN'S ROOM WATER CLOSET. REPIPE DRAIN ABOVE SECOND FLR CEILING WITH NEW 1-1/2" SAN RISER TO NEW LAVATORY LOCATION (THIRD ELOCATION)
- 8. EXISTING WATER SUPPLY AND SANITARY DRAIN RISERS IN EXISTING CHASE
- NEW CW & HW RISERS TO THIRD FLR SHOWER AND WATER CLOSET LOCATIONS, CONNECT TO EXISTING HW AND NEW CW SUPPLY PIPING ABOVE 2ND FLR CEILING.
- 10. NEW 1-1/2"CW SUPPLY RISER FROM FIRST FLR, IN NEW WALL. CONNECT TO EXISTING CW PIPING ABOVE THE SECOND FLR CEILING. MAINTAIN EXISTING CW RISER FROM FIRST FLR. THE INTENT WILL BE TO SUPPLEMENT WATER SUPPLY TO PLUMBING FIXTURES.
- 11. MODIFY AND PATCH EXISTING GYP BOARD SOFFIT AROUND EXISTING BUILDING FRAMING DUE TO INSTALLATION OF NEW PLUMBING PIPING TO NEW THIRD FLOOR FIXTURE LOCATIONS.
- EXISTING LAY—IN CEILINGS IN ROOMS AND CORRIDORS SHALL BE REPLACED DURING CONSTRUCTION. COORDINATE ALL PLUMBING PIPING WORK ABOVE 12. CEILINGS WITH CEILING REPLACEMENT.
- NEW HORIZONTAL AIR HANDLER WITH COOLING COIL ABOVE NEW CEILING, PROVIDE NEW 3/4" COPPER CONDENSATE DRAIN, CONNECT TO AIR HANDLER 13. DRAIN CONNECTION WITH TRAP. RUN CONDENSATE DRAIN FROM EACH UNIT ABOVE NEW CEILINGS TO A COMMON DROP TO BASEMENT. FIELD COORDINATE LOCATION OF DROP TO BASEMENT. DISCHARGE CONDENSATE INTO EXISTING SUMP PUMP BASIN IN BOILER ROOM.

RENOVATIONS TO:

second floor

Drawing Title:



AS BUILT

THIRD FLOOR PLUMBING PLAN

Drawing Title:

1/04/2006

Date:


May 25, 2004


Scale:

1/4" = 1'-0"

Drawn By:

Project Number:





RENOVATIONS TO:

35 CRESCENT STREET

STAMFORD, CONNECTICUT 06906

GLENBROOK COMMUNITY CENTER

# CONSTRUCTION NOTES

SERVICE INSTALLATION.

1. EXCAVATE EXIST. DRIVEWAY & GRADE AS REQUIRED TO INSTALL NEW WATER PIPING. BACKFILL AND RE-PAVE DRIVEWAY DUE TO NEW

MATERIAL

--

FIBERGLASS

STAINLESS STEEL

TERRAZZO

STAINLESS STEEL

--

--

AMERICAN STD

--

2305.100

- 2. RESEED GRASS AREAS DISTURBED BY THE INSTALLATION OF THE NEW WATER SERVICE(S).
- COORDINATE WITH AND PAY THE CITY FOR PATCHING OF THE CITY STREET DUE TO INSTALLATION OF THE NEW WATER SERVICE(S).

Revision: Description:	Date: Revised By:	Drawing Title:	Date: Drawing Number:
AS BUILT	1/04/2006		May 25, 2004
		SITE PLAN PLUMBING SCHEDULE	Scale: AS NOTED  Drawn By:  Project Number:

PLUMBING FIXTURE AND EQUIPMENT SCHEDULE

CARRIER MOUNTING

FLOOR MOUNTED | PROVIDE NEW FLANGE GASKET

FLOOR MOUNTED PROVIDE NEW FLANGE GASKET

FLOOR MOUNTED | 1.6 GAL PER FLUSH, WHITE

NOTES

PROVIDE NEW CHROME SUPPLIES, STOPS AND TRAP

PROVIDE NEW CHROME SUPPLIES, STOPS AND TRAP

FURNISH SHOWER FLOOR WITH GRID STRAINER DRAIN

WALL BRACKET PROVIDE NEW CHROME SUPPLIES, STOPS AND TRAP

WALL BRACKET PROVIDE NEW CHROME SUPPLIES, STOPS AND TRAP

COUNTER TOP PROVIDE NEW CHROME SUPPLIES, AND STOPS

TRIM/ACCESSORIES

2" SLOAN FLUSH VALVE # 113-1.6 (1.6 GPM), W/ NEW OPEN FRONT SEAT LESS COVER

-- AMERICAN STD FAUCET SET 6801.000.002, 8" CENTERS, CROWN HANDLES, POP-UP DRAIN

1/2" | 1/2" | 1-1/2" | 1-1/4" | 1-1/2" | AMERICAN STD FAUCET SET 5401.172H.002, 4" CENTERS, 4"BLADE HANDLES, POP-UP DRAIN, CLOSED CELL PIPE COVERS

1/2" | 1/2" | 1-1/2" | 1-1/4" | 1-1/2" | FURNISH W/ LKB-2479-8 GOOSENECK FAUCT SPOUT, D-5018A DRAIN W/ BASKET STRAINER, CHROME P-TRAP-CLEANOUT

1/2" | 1/2" | 2" | 1-1/2" | 32"X32" SHOWER, LEONARD AQUATROL 4501 W/ THERMOSTATIC - PRESSURE BALANCING VALVE, CHROME ADJUSTABLE HEADAKER

1/2" | 1/2" | 2" | 2" | -- | WOODFORD MODEL 22 BRASS FAUCET-FREEZEPROOF, ANTI-SIPHON WALL FAUCET - HOT AND COLD WATER, STAINLESS STEEL RIM GUARDS ON BASIN

-- | -- | -- | SLOAN FLUSH VALVE # 110 (3.5 GPM), W/ NEW OPEN FRONT SEAT LESS COVER


1" -- 3" -- 2" SLOAN FLUSH VALVE # 110 (3.5 GPM), W/ NEW OPEN FRONT SEAT LESS COVER


-- | -- | 1-1/4" | -- | AMERICAN STD FAUCET SET 5401.102H.002, 4" CENTERS, CROWN HANDLES, POP-UP DRAIN


1/2" | 1/2" | 1-1/2" | 1-1/4" | 1-1/2" | AMERICAN STD FAUCET SET 6801.000.002, 8" CENTERS, CROWN HANDLES, POP-UP DRAIN


1/2" | -- | 1-1/2" | 1-1/4" | 1-1/2" | SEMI-RECESSED FOUNTAIN


3/4" | -- | 2" | -- | 1-1/2" | SLOAN FLUSH VALVE # 186 (1.0 GPM)











	FIRE PR	OTECTION EQUIPMENT LEGEN	ID	
SYMBOL	DESCRIPTION	MANUFACTURER	MODEL NUMBER	REMARKS
0	1/2" SEMI-RECESSED SPRINKLER HEAD QUICK RESPONSE (FRANGIBLE BULB)	VIKING	MODEL M	CHROME PLATED FINISH AND ESCUTCHEON
•	1/2" UPRIGHT SPRINKLER HEAD QUICK RESPONSE (FRANGIBLE BULB)	VIKING	MODEL M	BRONZE FINISH
DCDA	DOUBLE CHECK DETECTOR ASSEMBLY	WATTS	757aDCDA OSY	
▽	1/2" SIDEWALL SPRINKLER HEAD QUICK RESPONSE (FRANGIBLE BULB)	STAR SPRINKLER CORP.	MODEL M	
D	1/2" SIDEWALL SPRINKLER HEAD DRY TYPE (FRANGIBLE HEAD)	STAR SPRINKLER CORP.	MODEL M	

# GENERAL NOTES - FIRE PROTECTION


- 1. THE SPRINKLER SYSTEM DESIGN SHALL BE BASED ON THE CONNECTICUT FIRE CODE AND NFPA 13 (2002). THE SPRINKLER SYSTEM SHALL BE A WET SYSTEM WITH THE EXCEPTION OF THE ATTIC SPACE AND THE STORAGE SPACE ADJACIENT TO THE TOILET ROOMS CONNECT TO THE BASEMENT WHICH WILL BE A DRY SYSTEM.
- THE FIRE PROTECTION CONTRACTOR SHALL COORDINATE WITH THE WATER UTILITY FOR A HYDRANT TEST TO ESTABLISH CURRENT STATIC / RESIDUAL PRESSURES, AND GPM FLOW RATES.
- 3. THE OCCUPANCY CLASSIFICATION OF THE BUILDING WILL BE A MIXED OCCUPANCY WITH A BUILDING HEIGHT LESS THAN 70 FEET AND APPROX 4400 SF/FLOOR. THE BULDING HAZARD CLASSIFICATION WILL BE AS FOLLOWS.
- BASEMENT LEVEL STORAGE & MECHANICAL RM. SHALL BE ORDINARY HAZARD GROUP I, SPRINKLER DENSITY SHALL BE .15 GPM FOR 1500 SF.
- <u>BASEMENT LEVEL</u> OFFICE AND GYMNASIUM SHALL BE LIGHT HAZARD WITH A SPRINKLER DENSITY OF 0.10 GPM FOR 1500 SF.
- THE 1ST. 2ND. AND 3RD FLOORS SHALL BE LIGHT HAZARD WITH A SPRINKLER DENSITY OF 0.10 GPM FOR 1500 SF.
- THE ATTIC SPACE SHALL BE A LIGHT HAZARD WITH A SPRINKLER DENSITY OF .010 GPM FOR 1950 SF.
- HOSE ALLOWANCE FOR LIGHT HAZARD DESIGN SHALL BE 100 GPM. HOSE ALLOWANCE FOR ORDINARY HAZARD SHALL BE 250 GPM.
- 4. THE EXISTING BUILDING STRUCTURE IS COMPRISED OF WOOD JOISTS/FRAMING AND WOOD FLOORING. SPRINKLER PROTECTION SHALL BE PROVIDED IN THE CONCEALED SPACES ABOVE THE NEW DROP CEILINGS WITHIN THE EXISTING BUILDING 5. STRUCTURE.
- THE FIRE PROTECTION SYSTEM WILL BE A SPRINKLER SYSTEM, WITH EACH FLOOR HAVING A SEPARATE ZONED SPRINKLER SUPPLY.
- 6. SPRINKLERS LOCATED IN DROP CEILINGS SHALL BE EITHER SEMI-RECESSED TYPE SPRINKLER HEADS. SPRINKLER HEADS IN EXPOSED AREAS W/O CEILINGS SHALL
- BE UPRIGHT SPRINKLER HEADS WITH A BRONZE FINISH. SIDEWALL SPRINKLER

  7. HEADS IN THE STAIRTOWERS SHALL HAVE A CHROME FINISH. ALL SPRINKLER
  HEADS SHALL BE A QUICK—RESPONSE TYPE AND HAVE A 135 DEG RATING
  UNLESS OTHERWISE NOTED.
- THE MANUFACTURE AND MODEL OF ALL FIRE PROTECTION CONTROL VALVES, ASSOCIATED EQUIPMENT, AND SPRINKLER HEADS SHALL BE FM & UL APPROVED.
- PROVIDE A REMOTE SPRINKLER TEST STATION FOR EACH SYSTEM, TERMINATE AT 8. AN EXTERIOR WALL IN AN ACCESSIBLE LOCATION(S). SEE DETAIL
- PRIOR TO ANY INSTALLATION OF THE NEW FIRE PROTECTION SYSTEM THE SPRINKLER CONTRACTOR SHALL PROVIDE/SUBMIT 2 SET OF THE HYDRAULIC CALCULATIONS AND SHOP DRAWINGS FOR THE FIRE PROTECTION SYSTEMS BASED
- 9. CALCULATIONS AND SHOP DRAWINGS FOR THE FIRE PROTECTION SYSTEMS BAS ON THE REQUIRED DENSITY AND HOSE STREAM REQUIREMENTS. TO THE FIRE MARSHALL FOR REVIEW. SUBMIT 4 COPIES OF APPROVED HYDRAULIC CALCULATIONS AND SHOP DRAWINGS TO ENGINNER FOR REVIEW.
- PROVIDE ENGRAVED SIGNS FOR EACH SPRINKLER SYSTEM STATING THE SYSTEM DESIGN PARAMETERS. HANG SIGNS ON ALARM VALVES WITH CHAINS. PROVIDE ENGRAVED SIGNS FOR ZONE CONTROL VALVE INDICATING ZONE. SUBMIT SHOP DRAWINGS FOR SIGNS AND LETTERING.
- PROVIDE SPRINKLER HEAD CABINET WITH SPARE SPRINKLER HEADS IN MECHANICAL ROOM.
- 11. THE SPRINKLER CONTRACTOR MUST COORDINATE THE INSTALLATION OF NEW SPRINKLER DISTRIBUTION MAINS WITH THE HVAC, ELECTRICAL, AND EXISTING STRUCTURE. FIELD COORDINATE ALL WORK.
- THESE DRAWINGS DO NOT SHOW SPRINKLER HEAD LOCATIONS FOR THE CONCEALED SPACES ABOVE THE DROP CEILINGS. SPRINKLER CONTRACTOR MUST 12. FIELD COORDINATE HEAD LOCATIONS DUE TO DUCT ROUTINGS AND FLOOR FRAMING.
- 1

RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET
STAMFORD, CONNECTICUT 06906



FIRE PROTECTION DETAILS

Drawing Title:

Date:


May 25, 2004


Scale:


1/4" = 1'-0"


Drawn By:

Project Number:









		EQL	JIPM	ENT	SCHE	DULE	$\langle \overline{XX} \rangle$
SYMBOL	VOLTAGE	PHASE	CIRCUIT AMPS	BREAKER	PANEL CIRCUIT	WIRE	CONNECTION
CU-1	208	1	30	30A/2P	A1-13,15	3 #10	NEMA 3R FUSED DISCONNECT
CU-2	208	1	45	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-3	208	1	45	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-4	208	1	60	NOTE 1	NOTE 1	3 #6	NEMA 3R FUSED DISCONNECT
CU-5	208	1	45	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-6	208	3	50	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-7	208	3	50	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-8	208	1	45	NOTE 1	NOTE 1	3 #8	NEMA 3R FUSED DISCONNECT
CU-9	208	1	60	NOTE 1	NOTE 1	3 #6	NEMA 3R FUSED DISCONNECT
AHU-1	208	1	20	20A/2P	F-1,3	4 #12	NEMA 1 FUSED DISC. & STARTER
AHU-2	208	1	20	20A/2P	F-2,4	4 #12	NEMA 1 NON-FUSED DISCONNECT
AHU-3	208	1	20	20A/2P	F-5,7	4 #12	NEMA 1 NON-FUSED DISCONNECT
AHU-4	208	1	20	20A/2P	A1-14,16	4 #12	NEMA 1 NON-FUSED DISCONNECT
AHU-5	208	1	20	20A/2P	A1-18,20	4 #12	NEMA 1 NON-FUSED DISCONNECT
AHU-6	208	1	20	20A/2P	F-6,8	4 #12	NEMA 1 FUSED DISC. & STARTER
UV-1	120	1	20	20A/1P	EXISTING	3 #12	NON-FUSED DISCONNECT
EF-1	120	1	20	20A/1P	EXISTING	3 #12	NON-FUSED DISCONNECT
EF-2	120	1	20	20A/1P	A1-17	3 #12	HARDWIRE TO DISC FURN. WITH UNIT
EF-3	120	1	20	20A/1P	F-11	3 #12	HARDWIRE TO DISC FURN. WITH UNIT
EF-4	120	1	20	20A/1P	F-9	3 #12	HARDWIRE TO DISC FURN. WITH UNIT
EF-5	120	1	20	20A/1P	PANEL B	3 #12	HARDWIRE TO DISC FURN. WITH UNIT
EF-6	120	1	20	20A/1P	EXISTING	3 #12	NON-FUSED DISCONNECT
EF-7	120	1	20	20A/1P	EXISTING	3 #12	NON-FUSED DISCONNECT
P-1	208	3	20	20A/3P	PANEL B	4 #12	NEMA 1 FUSED DISC. & STARTER

120 1 20 20A/1P EXISTING 3 #12 NON-FUSED DISCONNECT

1. SEVERAL CONDENSING UNITS ARE FED FROM A COMMON BRANCH CIRCUIT.
REFER TO PANELBOARD SCHEDULE & 1-LINE DIAGRAM.

- 2. DISCONNECT SWITCHES & MOTOR STARTERS LISTED SHALL BE FURNISHED AND INSTALLED BY ELECTRICAL CONTRACTOR UNLESS NOTED OTHERWISE.
- 3. PROVIDE ANY 120V WIRING REQUIRED TO INTERLOCK EQUIPMENT WITH HVAC CONTROLS.

7 | PLAN NOTES

I LAN NOTES

- 1 REPLACE EXISTING EXIT SIGN OR EMERGENCY LIGHT WITH NEW IN SAME LOCATION.
  2 REMOVE EXISTING WALL MOUNTED INCANDESCENT FIXTURE & INSTALL NEW FLUORESCENT
- WALL BRACKET IN SAME LOCATION.

  3 REMOVE EXISTING LIGHTS IN THIS AREA. INSTALL NEW IN NEW CEILING GRID AND CONNECT TO EXISTING CIRCUIT & SWITCH(ES)
- CONNECT TO EXISTING CIRCUIT & SWITCH(ES).

  (4) REPLACE EXISTING RECPETACLES IN THESE LOCATIONS WITH NEW AND PROVIDE ONE
- DEDICATED 120V, 20A BRANCH CIRCUIT FROM PANEL 'D' TO FEED THEM.

  (5) REMOVE EXISTING SURFACE MOUNTED FIXTURE & INSTALL NEW FLUORESCENT WRAP AROUND IN SAME LOCATION.
- 6 REPLACE EXISTING RECPETACLE WITH NEW IN SAME LOCATION. CONNECT TO EXISTING CIRCUIT. PROVIDE NEW COVERPLATE.
- 7 REMOVE EXISTING WALL MOUNTED FIXTURE. SECURE WIRING & PROVIDE APPROPRIATE COVERPLATE.
- PROVIDE NEW SWITCH & LIGHT FIXTURE FOR THIS SPACE. CONNECT TO EXISTING LIGHTING CIRCUIT IN THIS AREA.

   PROVIDE NEW RECEPTACLE IN THIS LOCATION AND DEDICATED 120V, 20A BRANCH CIRCUIT
- FROM PANEL 'D'.

  10 REMOVE EXISTING RECEPTACLE IN THIS LOCATION. PROVIDE NEW AT COUNTER LOCATION &
- CONNECT TO EXISTING CIRCUIT.

  (1) PROVIDE NEW 1000W INCANDESCENT DIMMERS FOR CONTROL OF NEW TRACK LIGHTS.
- PROVIDE ONE DEDICATED 120V, 20A BRANCH CIRCUIT FROM PANEL 'D'.

  12 PROVIDE NEW 1000W INCANDESCENT DIMMER FOR CONTROL OF NEW TRACK LIGHT
- PROVIDE NEW 1000W INCANDESCENT DIMMER FOR CONTROL OF NEW TRACK LIGHT.
  CONNECT TO EXISTING ROOM LIGHTING CIRCUIT.

  (13) PROVIDE NEW RECEPTACLE. CONNECT TO EXISTING CIRCUIT SERVING THIS AREA.
- 13) PROVIDE NEW RECEPTACLE. CONNECT TO EXISTING CIRCUIT SERVING THIS AREA.

  14) DISCONNECT POWER TO EXISTING AIR HANDLER IN THIS LOCATION & REMOVE WIRING BACK

REFER TO ARCHITECTURAL PHASING PLAN AND COORDINATE SCHEDULING OF ALL WORK WITH GENERAL CONTRACTOR & OWNER

Drawing Title:

RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET
STAMFORD, CONNECTICUT 06906

Revision: Description: Date: Revised By:

AS BUILT 1/04/2006

THIRD FLOOR ELECTRICAL PLAN Date:


MAY 25, 2004

Scale:

1/4" = 1'-0"

Drawn By:

E4



		MANUFACTURER/	LAN	<b>I</b> P			ELECTRICAL	_	NOTEC
DESIGNATION	DESCRIPTION	MODEL NUMBER	TYPE	COLOR TEMP	NO	BALLAST	VOLTAGE	WATTS	NOTES
A1	ACRYLIC LENS TROFFER 2'x4', RECESSED, GRID, STATIC	COLUMBIA JT824-232G-FS-A12.125-EB8-120	T8,32W, 48" STRAIGHT	4100K	2	ELECTRONIC	120	62	1
A2	ACRYLIC LENS TROFFER 2'x4', RECESSED, GRID, STATIC	COLUMBIA JT824-332G-FS-A12.125-EB8-120	T8,32W, 48" STRAIGHT	4100K	3	ELECTRONIC	120	89	1
A3	ACRYLIC LENS TROFFER 2'x2', RECESSED, GRID, STATIC	COLUMBIA JT822-231U1G-FS-A12.125-EB8-120	31W U-SHAPE	4100K	2	ELECTRONIC	120	62	1
B1	FLUORESCENT WALL BRACKET 4', SPEC GRADE	COLUMBIA WPM4-232-EB8-120	T8,32W, 48" STRAIGHT	4100K	2	ELECTRONIC	120	62	
C1	FLUORESCENT WRAP-AROUND 4', ACRYLIC REFRACTOR	COLUMBIA WC4-232-EB8-120	T8,32W, 48" STRAIGHT	4100K	2	ELECTRONIC	120	62	
D1	FLUORESCENT UTILITY LIGHT 14" ROUND, SURFACE MOUNT	LIGHTOLIER 6752WH226U	26 WATT DTT	4100K	2	ELECTRONIC	120	60	
D2	FLUORESCENT DOWNLIGHT 7" ROUND, LENSED, RECESSED	PRESCOLITE CFR826UEB-STQ1P-B6	26 WATT DTT	4100K	2	ELECTRONIC	120	60	
E1	EXIT LIGHT — SINGLE FACE SELF—CONTAINED, SURFACE MOUNT	PRESCOLITE NV3RENW	LED		1	NO BALLAST	120	3	45
E2	EMERGENCY LIGHTING UNIT SELF-CONTAINED, TWIN HEAD	PRESCOLITE NV2	5.4W INC.		2	NO BALLAST	120	20	6
E3	EMERGENCY LIGHTING UNIT SELF-CONTAINED, TWIN HEAD	PRESCOLITE NV5-0612-WGEL	12W INC.		2	NO BALLAST	120	20	67
E4	EMERGENCY LIGHTING UNIT SELF-CONTAINED, TWIN HEAD	PRESCOLITE NV5	5.4W INC.		2	NO BALLAST	120	20	6
E5	EMERGENCY LIGHTING REMOTE EXTERIOR HEAD	PRESCOLITE PEXT-0S0607	7.2W INC.		1	NO BALLAST	120	20	912
F1	VANDAL RESISTANT TROFFER 2'x2', RECESSED, GRID, STATIC	COLUMBIA 4VS22-340TTG-FS-LG250-EBTT-120-TP4	40W, TT 2G11 BASE	4100K	3	ELECTRONIC	120	115	3
G1	DECORATIVE CANOPY FIXTURE	KENALL MR17CD-P-MB-100M-1-120-QS	100W MH		1	HIGH POWER FACTOR	120	130	811
G2	EXTERIOR WALL PACK FIXTURE, SMALL HOUSING	LITHONIA TWR1C-100M-120-LPI	100W MH		1	NORM POWER FACTOR	120	130	9
G3	EXTERIOR WALL PACK FIXTURE, SMALL HORIZONTAL HOUSING	COOPER HPBC-HE-70-H120-BLK	70W HPS		1	HIGH POWER FACTOR	120	88	9
G4	DECORATIVE POLE LIGHT	MOLDCAST PCC-175MH-BLK/DB2-5F14-188	175W MH		1	NORM POWER FACTOR	120	215	10
T1	8' TRACK SECTION WITH 4 ROUNDBACK CYLINDER HEADS	PRESCOLITE AKT8-WH / AKTRCP20-WH	75W R-20		4	NO BALLAST	120	300	13

DESCRIPTION	NOTE	AMPS	TRIP AMP	POLE	CKT. TYP	CKT. NO.	A	вс	CKT. NO.	CKT. TYP	POLE	TRIP AMP	AMPS	NOTE	DESCRIPTION
AHU-1 (1.5 HP)		11.0	20	2	В	1			2	В	2	20	7.6 7.6		AHU-2 (3/4 HP)
AHU-3 (3/4 HP)		7.6 7.6	20	2	В	5 7			6 8	В	2	20	11.0		AHU-6 (1.5 HP)
EF-4 (1/4 HP)		5.8	20	1	Α	9	1		10						
EF-3 (1/2 HP)		10.8	20	1	Α	11	-		12						
						13	+	Н	14						
						15	$\vdash$		16						
						17	1	+	18						

PHASE B - 24.4 \( \rightarrow 10.9 \) KVA BASED ON 30.3 AMPS/PHASE

PHASE C - 29.4 )

6. CIRCUIT TYPE A: 120V, 3 WIRE IN CONDUIT OR MC CABLE.


7. CIRCUIT TYPE B: 208V, 1ø, 4 WIRE IN CONDUIT OR MC CABLE.

8. CIRCUIT TYPE C: 208V, 3ø, 5 WIRE IN CONDUIT OR MC CABLE.

50.0 50.0 50.0 48.0 48.0 66.0		3	TYP C	NO. 1 3	-	В		NO. 2	TYP		AMP	75.0		
50.0 50.0 48.0 48.0		3	С	<u> </u>		_								
50.0 48.0 48.0						-	<b>-</b> 1	4	С	3	100	75.0	(3)	CU-2,3,5&8
48.0	100			5		$\pm$		<u>'</u>		J	100	50.0		2,5,5&6
	100	1		7		$\pm$	$\pm \dagger$	8				30.0		
66.0	100	3	С	9		+	$\mp$	10	С	3	60	30.0		NEW PANEL 'F'
	1			11		+	+	12				30.0		
	20	1		13	-		$\pm 1$	14	В	2	20	5.4		AHU-4 (1/2 HP)
13.0	20	1	Α	15	$\exists$	+	$\pm 1$	16	ь		20	5.4		ANU-4 (1/2 NP)
5.8	20	1	Α	17		$\pm$		18	R	2	20	5.4		   AHU-5 (1/2 HP)
				19		$\pm$	$\pm \downarrow$	20			20	5.4		A10 5 (1/2 111)
				-		+	$\pm 1$							
				<u> </u>	H	+								
						$\mp$	$\dashv$							
				1	H	1	$\Box$							
				<u> </u>				JU						
F CUTI	ER-HA	AMMER	POW-	-R-LIN	ΙE	1 0	D [(		MATERIA					
					19 21 23 25 27 29	19 - 21 - 23 - 25 - 27 - 29 -	19 ————————————————————————————————————	19 ————————————————————————————————————	19 — 20 21 — 22 23 — 24 25 — 26 27 — 28 29 — 30	19 — 20 B 21 — 22 23 — 24 25 — 26 27 — 28 29 — 30	19 - 20 B 2 21 - 22 23 - 24 25 - 26 27 - 28 29 - 30	19	19 — 20 B 2 20 5.4  21 — 22  23 — 24  25 — 26  27 — 28  29 — 30	19 — 20 B 2 20 5.4  21 — 22  23 — 24  25 — 26  27 — 28  29 — 30

- 1) FURNISH W/ PRISMATIC ACRYLIC, 0.125" THICK, #12 PATTERN LENS.
- (3) FURNISH W/ .25" POLYCARBONATE LENS AND TAMPER RESISTANT SCREWS.
- (4) FURNISH W/ NICKEL CADMIUM BATTERY FOR 90 MINUTE EMERGENCY LIGHTING OPERATION. FURNISH THREE GYMNASIUM EXIT SIGNS WITH WIRE GUARDS.
- (5) PROVIDE W/ FEATURES & ACCESSORIES NECESSARY FOR UNIVERSAL (TOP, BACK, & END) MOUNTING AND UNIVERSAL DIRECTIONAL ARROW KNOCKOUTS. ARROWS ON PLANS INDICATE DIRECTION OF CHEVRONS.
- SHADING INDICATES FIXTURE FACE. CHEVRON & LETTERING SHALL COMPLY W/ NFPA 101.
- (6) FURNISH W/ SEALED LEAD-CALCIUM OR PURE LEAD BATTERY CAPABLE OF 90 MINUTE OPERATION.
- $\bigcirc$  FURNISH W/ WIRE GUARD.
- (8) UL LISTED FOR DAMP LOCATIONS.
- (9) UL LISTED FOR WET LOCATIONS.
- (10) FURNISH WITH 14' DECORATIVE CAST POLE & ANCHOR BOLTS. REFER TO DETAIL ON THIS SHEET.
- (1) FURNISH WITH DC QUARTZ LAMP SOCKET FOR EMERGENCY LIGHTING.
- (12) CONNECT TO BATTERY IN NEARBY E4 UNIT.
- (13) FURNISH W/ ALL REQUIRED END FEEDS, CONNECTORS, HANGERS, 90'S & HARDWARE.
- 15. FURNISH ALL FIXTURES WITH REQUIRED LAMPS. FLUORESCENT LAMPS SHALL PASS THE FEDERAL TCLP TEST FOR MERCURY TOXICITY AND SHALL BE CLASSIFIED AS NON-HAZARDOUS WASTE. ALL FLUORESCENT LAMPS SHALL BE MINIMUM 80 CRI AND EXP (LONG LIFE) RATED.

14. ELECTRONIC BALLAST SHALL HAVE MAXIMUM TOTAL HARMONIC DISTORTION OF TWENTY PERCENT (20%)



# FIRE ALARM LEGEND

- FACP ADDRESSABLE FIRE ALARM CONTROL PANEL
- FAAP LCD ANNUNCIATOR PANEL WITH SILENCE SWITCH
- MAGNETIC DOOR HOLDER
- ADA WALL MOUNT HORN/STROBE
- ADA WALL MOUNT STROBE ADDRESSABLE MANUAL FIRE ALARM PULL STATION — DOUBLE ACTION
- ADDRESSABLE PHOTOELECTRIC AREA SMOKE DETECTOR
- 135°F FIXED TEMPERATURE ADDRESSABLE HEAT DETECTOR
- ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR W/ CONTACT FOR CONNECTION TO ELEVATOR RECALL SYSTEM
- 135'F FIXED TEMPERATURE ADDRESSABLE HEAT DETECTOR W/ CONTACT FOR CONNECTION TO ELEVATOR SHUNT-TRIP BREAKER

ADDRESSABLE MODULE FOR MONITORING OF FLOW/PRESSURE/TAMPER SWITCH. SWITCHES ARE BY SPRINKLER CONTRACTOR. CONFIRM QUANTITY IN FIELD.

# FIRE ALARM RISER DIAGRAM

- ALL WIRING TO BE PER SPECIFICATIONS AND MANUFACTURER'S REQUIREMENTS. ② OMITTED.
- ③ PROVIDE WIRING AS REQUIRED TO ALLOW FOR SILENCING OF HORNS WITH STROBES STILL ACTIVE. ALL STROBES SHALL BE SYNCHRONIZED. PROVIDE APPROPRIATE MODULES FOR MONITORING OF NEW FLOW & TAMPER SWITCHES. ALL
- TAMPER SWITCHES IN ONE AREA MAY BE MONITORED BY ONE MODULE. EACH FLOW SWITCH SHALL HAVE ITS OWN MODULE. 5 REFER TO ELEVATOR RECALL & SHUNT TRIP SCHEMATICS ON THIS DRAWING FOR ADDITIONAL
- © FURNISH 1 HORN/STROBE, 1 STROBE, AND 4 SMOKE DETECTORS IN GYMNASIUM WITH WIRE
- REFER TO ELECTRICAL PLANS TO CONFIRM DEVICE QUANTITIES. B. FURNISH DEVICES WITH ALL NECESSARY MATERIALS AND ACCESSORIES FOR COMPLETE INSTALLATION TO BE FULLY OPERATIONAL.
- CONTRACTOR SHALL COORDINATE LOCATION OF ALL DUCT SMOKE DETECTORS WITH MECHANICAL CONTRACTOR. ALL DEVICES SHALL BE WIRED TO THE FIRE ALARM SYSTEM.
- EN. ALL FIRE ALARM WORK SHALL BE PERFORMED BY SONITROL. CONTRACTOR SHALL CONTACT \*\* AT \*\* TO OBTAIN PRICE FOR THIS WORK & CARRY THIS COST IN HIS BID.

EACH ADDITIONAL LEVEL LOWEST LEVEL ELEV. MACHINE RM. ELEV. PIT SCHEMATIC WIRING DIAGRAM

# ELEVATOR RECALL SMOKE DETECTORS


- 1) TIE INTO FIRE ALARM CONTROL PANEL.
- 2 PROVIDE ELEV. RECALL SMOKE DETECTORS IN ELEV. MACHINE RM AND AT EACH ELEV. DOOR OPENING ON EACH LEVEL.
- ③ IF ELEV. SHAFT/HOISTWAY IS SPRINKLERED, PROVIDE ELEV. RECALL SMOKE DETECTOR AT TOP OF SHAFT/HOISTWAY.
- 4. ALL WIRING PER FIRE ALARM SYSTEM MANUFACTURER'S REQUIREMENTS.
- 5. TYPICAL DEVICES SHOWN. REFER TO DWGS FOR QUANTITY. 6. COORDINATE ADDITIONAL REQUIREMENTS WITH ELEV. AND FIRE ALARM MANUFACTURERS AND
- 7. THREE SEPARATE "SIGNALS" SHALL BE PROVIDED:
- ONE (1) FOR TYPICAL LOBBY DETECTOR(S) - ONE (1) FOR DESIGNATED LEVEL LOBBY DETECTOR(S) - ONE (1) FOR THE ELEV. MACHINE RM AND SHAFT/HOISTWAY DETECTOR(S)

ELEV. MACHINE RM. 4 120V ← TO SHUNT TRIP RELAY SCHEMATIC WIRING DIAGRAM

# **ELEVATOR SHUNT-TRIP HEAT DETECTORS**

- 1 PROVIDE ELEV. SHUNT TRIP HEAT DETECTORS TO BE INSTALLED IN ELEV. MACHINE RM, TOP OF SHAFT AND IN PIT. REFER TO SPRINKLER AND FIRE PROTECTION DRAWINGS, QUANTITY OF DETECTORS SHALL MATCH THE NUMBER OF SPRINKLER HEADS IN ELEV. MACHINE RM AND SHAFT/HOISTWAY. LOCATION OF DETECTORS SHALL BE INSTALLED WITHIN 24" OF SPRINKLER HEAD. DETECTORS SHALL ALSO BE WIRED TO THE FIRE ALARM CONTROL PANEL.
- 2 PROVIDE SHUNT TRIP CIRCUIT BREAKER AT PANELBOARD.
- 3 PROVIDE RELAY IF REQUIRED FOR HEAT DETECTOR CONTACTS TO ACTIVATE SHUNT TRIP BREAKER.
- 4 PROVIDE DEDICATED 120V BRANCH CIRCUIT.
- 5. ALL WIRING PER FIRE ALARM SYSTEM MANUFACTURER'S REQUIREMENTS.
- 6. COORDINATE ADDITIONAL REQUIREMENTS WITH ELEV. AND FIRE ALARM MANUFACTURERS AND

REFER TO ARCHITECTURAL PHASING PLAN AND COORDINATE SCHEDULING OF ALL WORK WITH GENERAL CONTRACTOR & OWNER



# SCALE: NONE

# 1-LINE NOTES:

- (1) DISCONNECT POWER TO SNOW MELTING SYSTEM & LABEL AS INACTIVE. REFER TO PANELBOARD SCHEDULE ON THIS SHEET FOR NEW BREAKER
- REQUIREMENTS. PROVIDE NEMA 3R WIREWAY AS REQUIRED FOR TAPS TO CONDENSING UNIT
- 4 FURNISH & INSTALL NEW PANELBOARD. REFER TO PANELBOARD SCHEDULE
- ON THIS SHEET FOR DETAILS. 5 PROVIDE NEW 200A, 3-POLE, NEMA 1 FUSED DISCONNECT FOR PROPER
- PROTECTION OF EXISTING PANEL A1.
- (6) PROVIDE NEW GROUND CONNECTION TO WATER SERVICE ENTRANCE. GEN. DASHED LINES REPRESENT EXISTING CONDUIT & WIRE TO REMAIN.

Drawing Number: MAY 25, 2004 Scale: NONE

**LOAD CALCULATION:** 

PEAK DEMAND IN THE PAST YEAR WAS 46.6KVA. THIS

CORRESPONDS TO 130 AMPS. THE ADDED LOAD NEW

 $130A \times 1.25 + NEW LOAD (163A+150A) = 313 WHICH$ 

EQUIPMENT IS 150 AMPS. PER NEC 220-35;

IS LESS THAN THE 400A SERVICE RATING.

Project Number:

RENOVATIONS TO:

GLENBROOK COMMUNITY CENTER

35 CRESCENT STREET STAMFORD, CONNECTICUT 06906

6. CIRCUIT TYPE A: 120V, 3 WIRE IN CONDUIT OR MC CABLE.

7. CIRCUIT TYPE B: 208V, 1ø, 4 WIRE IN CONDUIT OR MC CABLE. 8. CIRCUIT TYPE C: 208V, 3ø, 5 WIRE IN CONDUIT OR MC CABLE.

> AS BUILT 1/04/2006

**ELECTRICAL SCHEDULES** AND DETAILS