

---

From: de la Cruz, Virgil

Sent: Tuesday, July 6, 2021 3:21 PM

To: Casolo, Louis

Cc: Rosenson, Valerie; McGrath, Mark

Subject: Re: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Thanks Lou,

Now I have a much better understanding.

Virgil

---

From: Casolo, Louis

Sent: Tuesday, July 6, 2021 3:12 PM

To: de la Cruz, Virgil

Cc: Rosenson, Valerie; McGrath, Mark

Subject: RE: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Water main is in the river bed and electric conduits are empty.

From: de la Cruz, Virgil

Sent: Tuesday, July 06, 2021 3:10 PM

To: Casolo, Louis

Cc: Rosenson, Valerie; McGrath, Mark

Subject: Re: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Thanks Lou,

How about potable water and electricity?

Virgil

---

From: Casolo, Louis

Sent: Tuesday, July 6, 2021 3:07:07 PM

To: de la Cruz, Virgil

Cc: Rosenson, Valerie; McGrath, Mark

Subject: RE: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Virgil:

Frontier has active telephone and communications on the bridge in 12 ducts.

Eversource has an active 6" low pressure gas main which they were planning to take out of service once we were to begin construction so that remains active.

Lou

From: de la Cruz, Virgil

Sent: Tuesday, July 06, 2021 2:40 PM

To: Casolo, Louis

Cc: Rosenson, Valerie; McGrath, Mark

Subject: Re: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Lou,

Thanks very much for the information; as always you try to be responsive.

My question was directed at clarifying my understanding of the utilities situation formed from discussions in prior meetings, which to my recollection was never corrected or updated.

If the West Main Street bridge were to collapse as feared, specially in a storm:

Will potable water, natural gas, electricity, and/or telephone service to residents in the area and elsewhere be lost and need to be restored?

Perhaps the answer is different for each utility. Please advise.

Regards,

Virgil

---

From: Casolo, Louis

Sent: Tuesday, July 6, 2021 12:11 PM

To: de la Cruz, Virgil

Cc: Rosenson, Valerie; McGrath, Mark

Subject: FW: RFP - West Main Street Bridge - Scop of Services Pre-Fabricated Bridge Option (2)

Representative de la Cruz:

As you requested at the 6/29/21 Operations Committee meeting, attached is utility information related to the Westmain Street bridge.

I have included the following information:

1. Existing utilities are shown on plan (sheet 1) and proposed configuration is shown in section on (sheet 2) of the first attachment. Eversource electric has requested 6-5" PVC conduits. Eversource gas has requested one 6" gas, Aquarion requested one 12" water, and Frontier requested 9, 4" fiberglass tele communications conduits.
2. I have also attached telephone record plans of exiting there appears to be 12, 4" aluminum conduits on the bridge which are active. 2nd attachment
3. From the 3rd attachment there are 4 empty conduits for Eversource electric nothing active.
4. From the 4rd attachment we were told Everosurce gas has one 6" DI low pressure gas main which will be put out of service during construction.
5. Project utility meeting minutes are noted on the 5th attachment.

Lou