

PS27.051

MAYOR  
DANNEL P. MALLOY



DIRECTOR OF OPERATIONS  
BENJAMIN BARNES

Tel: (203) 977-4141  
Fax: (203) 977-4723  
Email: bbarnes@ci.stamford.ct.us

**CITY OF STAMFORD**  
**OFFICE OF OPERATIONS**  
888 WASHINGTON BOULEVARD  
P.O. BOX 10152  
STAMFORD, CT 06904 - 2152

TO: Board of Representatives  
FROM: Dannel P. Malloy, Mayor *DPM*  
DATE: October 7, 2009

**RE: *Request for Water Main Extension and Waiver of Reimbursement for Mary Joy Lane and Alma Rock Road***

---

Based on a recommendation by Health Director Johnnie Lee that the above-mentioned roads should be connected to public drinking water supplies, the Office of Operations has prepared an estimate for a project consisting of water mains and service laterals. That recommendation, along with the estimate, are attached.

Given the urgent nature of this item, I am requesting that you approve at your earliest opportunity the following:

1. The connection of the designated area to the public water supply, including extension of water mains and service laterals; and
2. Waiver of all reimbursement by individual property owners for the costs of such extension.

Thank you for giving this matter your most urgent attention.

DPM/ma

Attachment

cc: Benjamin Barnes, Director of Operations  
Dr. Johnnie Lee, Director of Health  
Bill Callion, Director of Public Safety, Health and Welfare  
Lou Casolo, City Engineer

**Alma Rock/Mary Joy Water Main Extension**


<b>Street</b>	<b>Quantity</b>	<b>Unit</b>	<b>Unit Price</b>	<b>Cost</b>	<b>Comments</b>
<b>Mary Joy Lane</b>					
8" DI Main	350	LF	\$150.00	\$52,500.00	4 Parcels ***
1 1/2" services	900	LF	\$75.00	\$67,500.00	**
<b>Alma Rock Road</b> (includes 550 LF on High Ridge Road)					
8" DI Main	1500	LF	\$150.00	\$225,000.00	15 Parcels ***
1 1/2" services	2300	LF	\$75.00	\$172,500.00	**
<b>Plumbing Services</b>	19	Dwelling	\$2,000.00	<u>\$38,000.00</u>	Connections and Taps
<b>Sub-Total</b>				\$555,500.00	
<b>35% Contingency</b>				\$194,425.00	
<b>Total</b>				<b>\$749,925.00</b>	



**CITY OF STAMFORD**  
DEPARTMENT OF HEALTH & SOCIAL SERVICES  
STAMFORD GOVERNMENT CENTER  
888 WASHINGTON BOULEVARD  
STAMFORD, CT 06901-2902

# Memo

TO: Mayor Dannel P. Malloy

FROM: Johnnie A. Lee, MD, MPH, FACP  
Director of Health & Social Services 

CC: William Callion, Director of PSH&W  
Benjamin Barnes, Director of Operations

DATE: October 5, 2009

**RE: Contaminated Wells**

---

Laboratory tests of well water samples recently collected from residences in the vicinity of Scofieldtown Park reveal elevated levels of dieldrin and chlordane. Elevated levels of these chemicals negatively impact the quality of the drinking water. Mary Joy Lane and Alma Rock Road are located in close proximity to homes with wells contaminated with dieldrin and chlordane. In an effort to protect the health and safety of the residents of the homes on these streets, the residences should be connected to the City public water system as soon as possible.

I recommend that the homes on Mary Joy Lane and Alma Rock Road be connected to the public water supply by the extension of water mains.